

## Facility Summary in BROADWATER County in the City of TOWNSEND

<b>Owner:</b> Town Pump of Townsend Inc			<b>Address:</b> 600 South Main St, BUTTE MT 59701-2534		
<b>Sys Fac ID</b> 0403456	<b>FITS SITE</b> 32544	<b>Location Name</b> TOWN PUMP INC TOWNSEND	<b>Location Street Address</b> 206 N FRONT ST	<b>Location City</b> TOWNSEND, MT 59644	<b>Location Phone</b>
<b>Operating Permit Renewal Date:</b> 27-Oct-2012			<b>Last inspected on:</b> 21-Oct-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
7 / 07 Currently in Use	2386	3/15/1995 17 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F ● H ● K L ● D E F ● H ● K L	Yes Yes Yes
8 / 08 Currently in Use	2387	3/15/1995 17 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F ● H ● K L ● D E F ● H ● K L	Yes Yes Yes
9 / 09 Currently in Use	2388	3/15/1995 17 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F ● H ● K L ● D E F ● H ● K L	Yes Yes Yes
10 / 10 Currently in Use	2389	3/15/1995 17 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F ● H ● K L ● D E F ● H ● K L	Yes Yes Yes

<b>Owner:</b> Rocky Mountain Supply Inc			<b>Address:</b> Jason Rorabaugh Petroleum Mgr, 350 Jackrabbit Ln, Belgrade MT 59714-3035		
<b>Sys Fac ID</b> 0407862	<b>FITS SITE</b> 32596	<b>Location Name</b> ROCKY MOUNTAIN SUPPLY INC TOWNSEND	<b>Location Street Address</b> 310 S FRONT ST # 447	<b>Location City</b> TOWNSEND, MT 59644	<b>Location Phone</b> (406) 266-3456
<b>Operating Permit Renewal Date:</b> 15-Apr-2013			<b>Last inspected on:</b> 19-Jan-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 10 Currently in Use	4298	4/1/1995 17 / No	Diesel 4,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
8 / 08 Currently in Use	4299	4/1/1995 17 / No	Gasoline 4,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
9 / 09 Currently in Use	4300	4/1/1995 17 / No	Diesel 8,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
10 / 07 Currently in Use	4301	4/1/1995 17 / No	Gasoline 8,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A ● C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in BROADWATER County in the City of WINSTON

<b>Owner:</b> Allen L Brewer			<b>Address:</b> Winston Store LLC, PO Box 470186, Winston MT 59647-0186		
<b>Sys Fac ID</b> 0400280	<b>FITS SITE</b> 32502	<b>Location Name</b> WINSTON STORE LLC	<b>Location Street Address</b> 6473 US HIGHWAY 287	<b>Location City</b> WINSTON, MT 59647	<b>Location Phone</b> (406) 227-5597
<b>Operating Permit Renewal Date:</b> 01-Apr-2015			<b>Last inspected on:</b> 26-Jan-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
3 / 03 Currently in Use	3152	9/1/1993 18 / No	Gasoline 1,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="radio"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td><input checked="" type="radio"/></td><td>L</td></tr> </table>	A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	J	K	<input checked="" type="radio"/>	L	Yes Yes Yes
A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	J	K	<input checked="" type="radio"/>	L																					
4 / 04 Currently in Use	3153	9/1/1993 18 / No	Diesel 1,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="radio"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td><input checked="" type="radio"/></td><td>L</td></tr> </table>	A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	J	K	<input checked="" type="radio"/>	L	Yes Yes Yes
A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	J	K	<input checked="" type="radio"/>	L																					

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed