

Facility Summary in CHOUTEAU County in the City of BIG SANDY

Owner: EZZIES WHOLESALE INC			Address: PO Box 1770, Malta MT 59538-1770		
Sys Fac ID 0800855	FITS SITE 33645	Location Name EZZIES WHOLESALE BIG SANDY	Location Street Address FERRY STAR ROUTE PO BOX 236	Location City BIG SANDY, MT 59520	Location Phone (406) 378-2101
Operating Permit Renewal Date: 09-Jul-2013			Last inspected on: 09-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 12 Currently in Use	1841	6/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 10 Currently in Use	1842	5/18/1990 21 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 13 Currently in Use	1844	6/1/1992 19 / No	Gasoline 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 14 Currently in Use	1845	6/1/1992 19 / No	Gasoline 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
11 / 09 Currently in Use	1843	5/18/1990 21 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Mountain View Coop Black Eagle			Address: Attn Pat or Frank, 2200 Old Havre Hwy, Black Eagle MT 59414-1043		
Sys Fac ID 5614150	FITS SITE 45332	Location Name MOUNTAIN VIEW COOP BIG SANDY	Location Street Address 79211 US HIGHWAY 87	Location City BIG SANDY, MT 59520	Location Phone
Operating Permit Renewal Date: 27-Apr-2014			Last inspected on: 28-Jan-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1 Currently In Use	4965	1/31/2005 07 / Yes	Gasoline 5,000	Epoxy Coated Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / S2 Currently In Use	4966	1/31/2005 07 / Yes	Diesel 5,000	Epoxy Coated Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / S3 Temporarily Out of Use	4967	/ Yes	Unknown 1	Epoxy Coated Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / S4 Temporarily Out of Use	4968	/ Yes	Unknown 1	Epoxy Coated Steel None	Flexible Plastic Double-Walled	Not Listed	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of CARTER

Owner: Schuler Lands Inc			Address: 17105 Dent Bridge Rd, Carter MT 59420-0036		
Sys Fac ID 0803976	FITS SITE 33713	Location Name SCHULER LANDS EAST FARM	Location Street Address 17105 DENT BRIDGE RD	Location City CARTER, MT 59420	Location Phone (406) 734-5404
Operating Permit Renewal Date: 21-Nov-2012			Last inspected on: 08-Jul-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 01 Currently In Use	4133	4/22/1982 30 / No	Gasoline 9,000	Fiberglass Reinforced Plastic None	No Piping None	Pressurized	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="radio"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	J	K	L		Yes Yes Yes
A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	J	K	L																						

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 0809076	FITS SITE 33843	Location Name MALMSTROM AFB J 3	Location Street Address US HIGHWAY 87	Location City CARTER, MT 59420	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	157	8/1/1991 20 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 0809078	FITS SITE 33845	Location Name MALMSTROM AFB J 5	Location Street Address US HIGHWAY 87	Location City CARTER, MT 59420	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	159	8/1/1991 20 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of FORT BENTON

Owner: Riverside Business Inc			Address: 5809 Gooch Hill Rd, Bozeman MT 59718-9060		
Sys Fac ID 0800093	FITS SITE 33616	Location Name JOYCE STORE 1	Location Street Address 1221 MAIN ST PO Box 1208	Location City FORT BENTON, MT 59442	Location Phone (406) 622-3381
Operating Permit Renewal Date: 20-Nov-2013			Last inspected on: 27-Aug-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently in Use	4134	6/1/1999 12 / No	Gasoline 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently in Use	4135	6/1/1999 12 / No	Gasoline 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
6 / 06 Currently in Use	4136	6/1/1999 12 / No	Gasoline 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Choteau County			Address: PO Box 459, Fort Benton MT 59442-0459		
Sys Fac ID 0805930	FITS SITE 33767	Location Name COUNTY COURTHOUSE & JAIL	Location Street Address 1215 WASHINGTON ST	Location City FORT BENTON, MT 59442	Location Phone (406) 622-3631
Operating Permit Renewal Date: 09-Sep-2014			Last inspected on: 13-Apr-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4118	6/1/1988 23 / No	Diesel 550	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	U.S. Suction	● A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Perry Joyce			Address: PO Box 66, Geraldine MT 59446-0066		
Sys Fac ID 5613981	FITS SITE 45188	Location Name JOYCE FUEL & FEEDS FORT BENTON	Location Street Address 2118 SAINT CHARLES ST	Location City FORT BENTON, MT 59442	Location Phone (406) 622-3363
Operating Permit Renewal Date: 14-Jan-2015			Last inspected on: 10-Aug-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4210	7/27/2000 11 / No	Gasoline 3,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of FORT BENTON

2 / 02	4211	7/27/2000	Gasoline	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1"> <tr> <td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="12"> </td> </tr> <tr> <td colspan="12"> </td> </tr> <tr> <td>B</td><td>●</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td colspan="2"> </td> </tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L																									B	●	E	F	●	H	I	J	K	L			Yes	Yes	Yes
A	B	C	●	E	F	G	H	I	J	K	L																																															
B	●	E	F	●	H	I	J	K	L																																																	
Currently In Use	11 / No	3,000	None	Double-Walled																																																						
3 / 03	4212	7/27/2000	Diesel	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1"> <tr> <td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="12"> </td> </tr> <tr> <td colspan="12"> </td> </tr> <tr> <td>B</td><td>●</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td colspan="2"> </td> </tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L																									B	●	E	F	●	H	I	J	K	L			Yes	Yes	Yes
A	B	C	●	E	F	G	H	I	J	K	L																																															
B	●	E	F	●	H	I	J	K	L																																																	
Currently In Use	11 / No	3,000	None	Double-Walled																																																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of GERALDINE

Owner: Central Montana Coop Geraldine		Address: PO Box 330, Geraldine MT 59446-0330	
Sys Fac ID 0806615	FITS SITE 33784	Location Name CENTRAL MONTANA COOP GERALDINE	Location Street Address MT HIGHWAY 80
		Location City GERALDINE, MT 59446	Location Phone (406) 737-4480
Operating Permit Renewal Date: 08-Jul-2013		Last inspected on: 20-May-2010	

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / S1 Currently in Use	864	4/29/1974 37 / Yes	Gasoline 2,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>L</td></tr> <tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L	No No Yes
A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L																					
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																					
2 / S2 Currently in Use	865	4/29/1974 37 / Yes	Gasoline 2,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>L</td></tr> <tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L	Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L																					
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																					

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of LOMA

Owner: Garvey C Wood		Address: PO Box 207, Loma MT 59460-0207	
Sys Fac ID 0801445	FITS SITE 33657	Location Name MIDWAY MERCANTILE	Location Street Address 204 BROADWAY
		Location City LOMA, MT 59460	Location Phone (406) 739-4225
Operating Permit Renewal Date:		Last inspected on: 28-May-2009	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 03 Temporarily Out of Use	3957	12/30/1986 25 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td><input checked="" type="checkbox"/></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td><input checked="" type="checkbox"/></td><td>J</td><td>K</td><td>L</td></tr> <tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td><td></td></tr> </table>	A	B	<input checked="" type="checkbox"/>	D	E	F	G	H	<input checked="" type="checkbox"/>	J	K	L	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L			Yes Yes Yes
A	B	<input checked="" type="checkbox"/>	D	E	F	G	H	<input checked="" type="checkbox"/>	J	K	L																					
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																							
2 / 04 Temporarily Out of Use	3958	12/30/1986 25 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td><input checked="" type="checkbox"/></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td><input checked="" type="checkbox"/></td><td>J</td><td>K</td><td>L</td></tr> <tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td><td></td></tr> </table>	A	B	<input checked="" type="checkbox"/>	D	E	F	G	H	<input checked="" type="checkbox"/>	J	K	L	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L			Yes Yes Yes
A	B	<input checked="" type="checkbox"/>	D	E	F	G	H	<input checked="" type="checkbox"/>	J	K	L																					
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																							

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in CHOUTEAU County in the City of RURAL LOCATION

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 0809077	FITS SITE 33844	Location Name MALMSTROM AFB J 4	Location Street Address US HIGHWAY 87	Location City RURAL LOCATION, MT	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	158	8/1/1991 20 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 0809079	FITS SITE 33846	Location Name MALMSTROM AFB J 6	Location Street Address US HIGHWAY 87	Location City RURAL LOCATION, MT	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	160	5/21/1989 22 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	U.S. Suction	A B C D E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 0809080	FITS SITE 33847	Location Name MALMSTROM AFB J 7	Location Street Address US HIGHWAY 87	Location City RURAL LOCATION, MT	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	161	8/1/1991 20 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed