

Facility Summary in DANIELS County in the City of FLAXVILLE

Owner: L D C		Address: PO Box 31, Flaxville MT 59222-0031			
Sys Fac ID 1001118	FITS SITE 34075	Location Name FLAXVILLE LOCAL NON PROFIT DEVELOPMEN	Location Street Address 400 1ST AVE	Location City FLAXVILLE, MT 59222	Location Phone (406) 480-5802
Operating Permit Renewal Date: 22-Aug-2011			Last inspected on: 04-Aug-2011		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / S4 Temporarily Out of Use	1889	8/2/1996 15 / No	Heating Oil 4,000	STI-P3 None	Flexible Plastic Double-Walled	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="checkbox"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L	B		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	H	I	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L																					
B		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	H	I	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	K	L																					

Owner: Grain Growers Oil Co		Address: PO Box 847, Scobey MT 59263-0847			
Sys Fac ID 1001331	FITS SITE 34080	Location Name GRAIN GROWERS OIL CO FLAXVILLE	Location Street Address MT HIGHWAY 5 & MAIN ST	Location City FLAXVILLE, MT 59222	Location Phone
Operating Permit Renewal Date: 23-Feb-2013			Last inspected on: 19-Aug-2009		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
4 / 04 Currently in Use	1225	7/31/1991 20 / No	Gasoline 2,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	K	L																					
5 / 05 Currently in Use	1226	7/31/1991 20 / No	Gasoline 2,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	K	L																					

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in DANIELS County in the City of SCOBEEY

Owner: Cromwells Convenience & Petroleum			Address: Railroad Ave W & Main St, PO Box 990, Scobey MT 59263-0990		
Sys Fac ID 1001223	FITS SITE 34078	Location Name CROMWELLS CONVENIENCE & PETROLEUM	Location Street Address 3 MAIN ST	Location City SCOBEEY, MT 59263	Location Phone (406) 487-2441
Operating Permit Renewal Date: 15-Jun-2013			Last inspected on: 20-May-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / S4 Currently in Use	2176	5/1/1996 15 / Yes	Gasoline 5,800	Other None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
5 / S5 Currently in Use	2177	5/1/1996 15 / Yes	Gasoline 12,000	Other None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
6 / S6 Currently in Use	2178	5/1/1996 15 / Yes	Diesel 12,000	Other None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
7 / S7 Currently in Use	2179	5/1/1996 15 / Yes	Diesel 10,000	Other None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Owner: Grain Growers Oil Co			Address: PO Box 847, Scobey MT 59263-0847		
Sys Fac ID 1003710	FITS SITE 34107	Location Name GRAIN GROWERS OIL CO PUMP 24	Location Street Address 108 1ST ST	Location City SCOBEEY, MT 59263	Location Phone (406) 487-2741
Operating Permit Renewal Date: 23-Feb-2013			Last inspected on: 20-Aug-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 04 Currently in Use	1227	10/1/1994 17 / No	Gasoline 12,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
5 / 05 Currently in Use	1228	10/1/1994 17 / No	Gasoline 12,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
6 / 06 Currently in Use	1229	10/1/1994 17 / No	Diesel 12,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
7 / 07 Currently in Use	1230	10/1/1994 17 / No	Diesel 12,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
8 / 08 Currently in Use	1231	10/1/1994 17 / No	Diesel 8,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
9 / 09 Currently in Use	1232	10/1/1994 17 / No	Diesel 4,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in DANIELS County in the City of SCOBHEY

Owner: Grain Growers Oil Co			Address: PO Box 847, Scobey MT 59263-0847		
Sys Fac ID 1004159	FITS SITE 34117	Location Name GRAIN GROWERS OIL CO SCOBHEY	Location Street Address 3 DANIELS ST	Location City SCOBHEY, MT 59263	Location Phone (406) 487-2741
Operating Permit Renewal Date: 23-Feb-2013			Last inspected on: 20-Aug-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
10 / S10 Currently in Use	5133	10/10/2008 03 / Yes	Gasohol/Eth 3,000	Unknown Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> L B <input checked="" type="radio"/> E F <input checked="" type="radio"/> H I J K L	Yes Yes No
11 / S11 Currently in Use	5134	10/10/2008 03 / Yes	Diesel 3,000	Unknown Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> L B <input checked="" type="radio"/> E F <input checked="" type="radio"/> H I J K L	Yes Yes No

Owner: Nemont Communications Inc			Address: MT Highway 13 S, PO Box 600, Scobey MT 59263-0600		
Sys Fac ID 1013610	FITS SITE 34227	Location Name NEMONT COMMUNICATIONS INC	Location Street Address MT HIGHWAY 13 S	Location City SCOBHEY, MT 59263	Location Phone
Operating Permit Renewal Date: 23-Feb-2013			Last inspected on: 20-Aug-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	3293	4/1/1995 17 / No	Waste Oil 100	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Gravity Feed	A B C D E F G H I J <input checked="" type="radio"/> L B <input checked="" type="radio"/> D E F G H I J <input checked="" type="radio"/> L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed