

## Facility Summary in GARFIELD County in the City of JORDAN

<b>Owner:</b> Farmers Union Oil Co Jordan			<b>Address:</b> PO Box 449, Jordan MT 59337-0449		
<b>Sys Fac ID</b> 1705702	<b>FITS SITE</b> 36423	<b>Location Name</b> FARMERS UNION OIL CO JORDAN	<b>Location Street Address</b> MT HIGHWAY 200	<b>Location City</b> JORDAN, MT 59337	<b>Location Phone</b> (406) 557-2215
<b>Operating Permit Renewal Date:</b> 19-Aug-2014			<b>Last inspected on:</b> 10-May-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
6 / 06 Currently In Use	941	12/1/1998 13 / No	Gasoline 12,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	942	12/1/1998 13 / No	Gasoline 4,100	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
8 / 08 Currently In Use	943	12/1/1998 13 / No	Diesel 4,100	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
9 / 09 Currently In Use	944	12/1/1998 13 / No	Diesel 3,760	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
10 / 10 Currently In Use	945	12/1/1998 13 / No	Diesel 7,900	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
11 / 11 Currently In Use	946	12/1/1998 13 / No	Diesel 4,100	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

<b>Owner:</b> Fellmans Hardware Inc			<b>Address:</b> C Corp, PO Box 344, Jordan MT 59337-0344		
<b>Sys Fac ID</b> 1710707	<b>FITS SITE</b> 36440	<b>Location Name</b> FELLMANS HARDWARE INC	<b>Location Street Address</b> MT HIGHWAY 200	<b>Location City</b> JORDAN, MT 59337	<b>Location Phone</b> (406) 557-2392
<b>Operating Permit Renewal Date:</b> 07-Nov-2013			<b>Last inspected on:</b> 20-Aug-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently In Use	4311	6/1/2001 10 / No	Gasoline 8,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4312	6/1/2001 10 / No	Gasoline 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	4313	6/1/2001 10 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed