

Facility Summary in GLACIER County in the City of BABB

Owner: Thronsons Store			Address: PO Box 169, Babb MT 59411-0169		
Sys Fac ID 1803871	FITS SITE 36494	Location Name THRONSONS STORE	Location Street Address US HIGHWAY 89	Location City BABB, MT 59411	Location Phone
Operating Permit Renewal Date: 03-Sep-2014			Last inspected on: 13-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Installed Spill/Over/CPMe																								
							Piping Release Detection																									
1 / 07 Currently in Use	4401	12/31/1989 22 / No	Gasoline 7,000	Cathodically Protected Steel Double-Walled	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>																					
2 / 08 Currently in Use	4402	12/31/1989 22 / No	Gasoline 3,000	Cathodically Protected Steel Double-Walled	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>																					
3 / 06 Currently in Use	4403	12/31/1989 22 / No	Gasoline 8,000	Cathodically Protected Steel Double-Walled	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td><td><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>																					

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of BROWNING

Owner: School Dist 9 Browning			Address: PO Box 610, Browning MT 59417-0610		
Sys Fac ID 1803868	FITS SITE 36492	Location Name SCHOOL DIST 9 MAINTENANCE COMPLEX	Location Street Address BOUNDARY ST	Location City BROWNING, MT 59417	Location Phone (406) 338-2952
Operating Permit Renewal Date: 23-Sep-2013			Last inspected on: 19-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	4130	11/29/1986 25 / No	Gasoline 8,000	STI-P3 Impressed Current	Galvanized Steel None	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently in Use	4131	11/28/1989 22 / No	Diesel 8,000	Polyethylene Tank Jacket Impressed Current	Galvanized Steel None	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Glacier Park 66 INC			Address: PO Box 1609, Browning MT 59417		
Sys Fac ID 1805813	FITS SITE 36525	Location Name GLACIER WAY C-STORE #2	Location Street Address 330 W CENTRAL AVE PO BOX 129	Location City BROWNING, MT 59417	Location Phone (406) 338-7615
Operating Permit Renewal Date: 13-Mar-2015			Last inspected on: 07-Mar-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently in Use	4441	1/3/1997 15 / No	Gasoline 20,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L D E F G H I J K L	Yes Yes Yes
5 / 05 Currently in Use	4442	1/3/1997 15 / No	Diesel 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L D E F G H I J K L	Yes Yes Yes
6 / 06 Currently in Use	4443	1/3/1997 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L D E F G H I J K L	Yes Yes Yes

Owner: Neil & Kathryn Miller			Address: HC 72 Box 5, BROWNING MT 59417-9701		
Sys Fac ID 1806436	FITS SITE 36534	Location Name PARK CAFE AND GROCERY SAINT MARY	Location Street Address 3147 US HIGHWAY 89 HC 72 Box 5	Location City BROWNING, MT 59417	Location Phone
Operating Permit Renewal Date: 11-Jun-2012			Last inspected on: 20-May-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
-----------------------------	---------------	----------------------	---------------------	--	-------------------------------------	-------------	--	------------------------------

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of BROWNING

1 / 07	1382	11/1/1991	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L			
Temporarily Out of Use		20 / No	2,000	None	None		<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
2 / 05	1380	11/1/1991	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L			
Temporarily Out of Use		20 / No	12,000	None	None		<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
3 / 06	1381	11/1/1991	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L			
Temporarily Out of Use		20 / No	6,000	None	None		<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes

Owner: Major Brands Distributing Imports Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 1808677	FITS SITE 36556	Location Name TOWN PUMP INC BROWNING 2	Location Street Address US HIGHWAY 89	Location City BROWNING, MT 59417	Location Phone
Operating Permit Renewal Date: 01-Apr-2013			Last inspected on: 11-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe
							Piping Release Detection		
1 / 13 Currently in Use	2467	6/1/1995 16 / No	Diesel 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
2 / 11 Currently in Use	2465	6/1/1995 16 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
3 / 12 Currently in Use	2466	6/1/1995 16 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
4 / 10 Currently in Use	4888	6/1/1995 16 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
13 / 09 Currently in Use	2463	6/1/1995 16 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
14 / 14 Currently In Use	4859	8/14/2003 08 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
15 / 15 Currently In Use	4860	8/14/2003 08 / No	Diesel 5,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	<input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes

Owner: School Dist 9 Browning			Address: PO Box 610, Browning MT 59417-0610		
Sys Fac ID 1812747	FITS SITE 36583	Location Name SCHOOL DIST 9 TRANSPORTATION DEPT	Location Street Address 829 SW BOUNDARY ST	Location City BROWNING, MT 59417	Location Phone (406) 338-2952
Operating Permit Renewal Date: 23-Sep-2013			Last inspected on: 19-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe
							Piping Release Detection		

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of BROWNING

1 / 03	1900	7/1/1992	Waste Oil	STI-P3	Flexible Plastic	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
Currently in Use		19 / No	1,000	None	Double-Walled					
2 / 01	1898	7/1/1992	Gasoline	STI-P3	Fiberglass Reinforced Plas	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input checked="" type="checkbox"/> C <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
Currently in Use		19 / No	8,000	None	None					
3 / 02	1899	7/1/1992	Diesel	STI-P3	Fiberglass Reinforced Plas	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input checked="" type="checkbox"/> C <input checked="" type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
Currently in Use		19 / No	8,000	None	None					

Owner: Pat & Violet Schildt		Address: PO Box 1777, Browning MT 59417-1777			
Sys Fac ID 1813768	FITS SITE 36594	Location Name GLACIER WAY CONVENIENCE STORE	Location Street Address STARR SCHOOL RD & DUCK LAKE RD	Location City BROWNING, MT 59417	Location Phone (406) 338-7163
Operating Permit Renewal Date: 20-Dec-2014		Last inspected on: 09-Dec-2011			

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe	
							Piping Release Detection			
1 / 01 Currently in Use	3425	9/25/1996 15 / No	Gasoline 20,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
2 / 02 Currently in Use	3426	9/25/1996 15 / No	Diesel 15,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes
3 / 03 Currently in Use	3427	9/25/1996 15 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input checked="" type="checkbox"/> C <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes	Yes	Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of CUT BANK

Owner: Cut Bank Airport Authority			Address: 2705 Valier Hwy, Cut Bank MT 59427		
Sys Fac ID 1800137	FITS SITE 36448	Location Name CUT BANK MUNICIPAL AIRPORT	Location Street Address 2705 VALIER HIGHWAY	Location City CUT BANK, MT 59427	Location Phone (406) 873-8683
Operating Permit Renewal Date: 31-Jan-2014			Last inspected on: 17-Jan-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
8 / 08 Currently In Use	793	11/1/1997 14 / No	Other 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
9 / 09 Currently In Use	794	11/1/1997 14 / No	Other 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Owner: Kennys Super Service			Address: 401 E Main St, Cut Bank MT 59427-3014		
Sys Fac ID 1800321	FITS SITE 36452	Location Name KENNYS SUPER SERVICE	Location Street Address 401 E MAIN ST	Location City CUT BANK, MT 59427	Location Phone (406) 873-2432
Operating Permit Renewal Date: 04-Nov-2014			Last inspected on: 06-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	1471	6/13/1985 26 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● K L	Yes Yes Yes
2 / 02 Currently in Use	1472	6/13/1985 26 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● K L	Yes Yes Yes

Owner: Town Pump O Mat of Cut Bank Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 1803417	FITS SITE 36487	Location Name TOWN PUMP INC CUT BANK 2	Location Street Address 510 W MAIN ST	Location City CUT BANK, MT 59427	Location Phone (406) 873-2208
Operating Permit Renewal Date: 01-Apr-2013			Last inspected on: 11-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	2459	3/1/1993 19 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L ● ● E F ● H ● ● K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of CUT BANK

Owner: Simons Petroleum Inc			Address: PO Box 644, Shelby MT 59474-0644		
Sys Fac ID 5613775	FITS SITE 45009	Location Name SIMONS BULK PLANT CUT BANK SATELLITE	Location Street Address 813 E RAILROAD ST	Location City CUT BANK, MT 59427	Location Phone (406) 434-2431
Operating Permit Renewal Date: 30-Jul-2014			Last inspected on: 10-Mar-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1 Currently In Use	1928	10/31/1997 14 / Yes	Diesel 12,000	Asphalt Coated or Bare Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes
2 / S2 Currently In Use	1929	10/31/1997 14 / Yes	Gasoline 8,000	Asphalt Coated or Bare Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: Manhattan Holdings LLC			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 6015144	FITS SITE 45445	Location Name TOWN PUMP OF CUT BANK #3	Location Street Address 1119 E MAIN ST	Location City Cut Bank, MT 59427	Location Phone (406) 497-6700
Operating Permit Renewal Date: 18-Jan-2014			Last inspected on: 25-Oct-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	5227	/ No	Gasoline 20,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L B D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L	Yes Yes Yes
2 / 02 Currently in Use	5228	/ No	Diesel 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L B D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L	Yes Yes Yes
3 / 03 Currently in Use	5229	/ No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L B D E F <input checked="" type="radio"/> H <input checked="" type="radio"/> J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of EAST GLACIER PARK

Owner: Judy Jones			Address: PO Box 275, East Glacier Park MT 59434-0275		
Sys Fac ID 1803870	FITS SITE 36493	Location Name SEARS MOTEL & GIFT SHOP	Location Street Address 1023 MT HIGHWAY 49 N	Location City EAST GLACIER PARK, MT 59	Location Phone (406) 226-4432
Operating Permit Renewal Date: 03-Jun-2012			Last inspected on: 20-May-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 03 Currently in Use	1453	9/28/1990 21 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● K L	Yes Yes Yes
3 / 04 Currently in Use	1454	9/1/1990 21 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● K L	Yes Yes Yes

Owner: Fortune Development Corp			Address: PO Box 468, East Glacier Park MT 59434-0468		
Sys Fac ID 5613933	FITS SITE 45148	Location Name BEAR TRACK TRAVEL CENTER	Location Street Address 20958 US HIGHWAY 2	Location City EAST GLACIER PARK, MT 59	Location Phone (406) 226-5504
Operating Permit Renewal Date: 30-Jun-2013			Last inspected on: 22-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1 Currently In Use	4068	6/1/1999 12 / Yes	Diesel 8,000	Unknown Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● K L B D E F ● H I J K L	Yes Yes Yes
2 / S2 Currently In Use	4069	6/1/1999 12 / Yes	Gasoline 5,000	Unknown Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● K L B D E F ● H I J K L	Yes Yes Yes
3 / S3 Currently in Use	5126	9/14/2007 04 / Yes	Gasoline 12,000	Concrete Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● K L B D E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GLACIER County in the City of SAINT MARY

Owner: Glacier Park Inc			Address: PO Box 147, East Glacier Park MT 59434		
Sys Fac ID 1801907	FITS SITE 36469	Location Name ST MARY LODGE	Location Street Address US HIGHWAY 89 ST MARY LAKE	Location City SAINT MARY, MT 59417	Location Phone (406) 732-4431
Operating Permit Renewal Date: 20-Oct-2014			Last inspected on: 19-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 03 Currently in Use	453	6/1/1990 21 / No	Gasoline 7,000	STI-P3 None	Fiberglass Reinforced Plas Secondary Containment C	Pressurized	A B C D E F G H I J K L B ● E F G H I J K L	Yes Yes Yes
2 / 04 Currently in Use	454	6/1/1990 21 / No	Diesel 3,000	STI-P3 None	Fiberglass Reinforced Plas Secondary Containment C	Pressurized	A B C D E F G H I J K L B ● E F G H I J K L	Yes Yes Yes
3 / 01 Currently in Use	451	6/1/1990 21 / No	Gasoline 15,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L B ● E F G H I J K L	Yes Yes Yes
4 / 02 Currently in Use	452	6/1/1990 21 / No	Gasoline 15,000	STI-P3 None	Fiberglass Reinforced Plas Secondary Containment C	Pressurized	A B C D E F G H I J K L B ● E F G H I J K L	Yes Yes Yes

Owner: Glacier National Park			Address: PO Box 128, West Glacier MT 59936-0128		
Sys Fac ID 1802745	FITS SITE 36484	Location Name SAINT MARY RANGER STATION	Location Street Address NATIONAL PARK SERVICE	Location City SAINT MARY, MT 59417	Location Phone (406) 888-7978
Operating Permit Renewal Date: 22-Dec-2013			Last inspected on: 01-Jul-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently in Use	1221	7/1/1987 24 / No	Gasoline 12,000	STI-P3 None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently in Use	1222	9/1/1992 19 / No	Diesel 4,000	STI-P3 Double-Walled	Fiberglass Reinforced Plas Double-Walled	Safe Suction	A B C D E F ● H I J K L B D E F G H I J ● L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed