

Facility Summary in GOLDEN VALLEY County in the City of LAVINA

Owner: Fastgo Service		Address: PO Box 242, Lavina MT 59046-0242	
Sys Fac ID 1913681	FITS SITE 36620	Location Name FAST GO SERVICE	Location Street Address 4666 MT Highway 3
		Location City LAVINA, MT 59046	Location Phone (406) 636-4005
Operating Permit Renewal Date: 24-Oct-2013		Last inspected on: 20-Aug-2010	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / S1 Currently in Use	3381	3/1/1996 16 / Yes	Diesel 10,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="checkbox"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L	B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L																					
B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L																						
2 / S2 Currently in Use	3382	3/1/1996 16 / Yes	Gasoline 10,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: small; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td><input checked="" type="checkbox"/></td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="checkbox"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L	B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	<input checked="" type="checkbox"/>	L																					
B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in GOLDEN VALLEY County in the City of RYEGATE

Owner: School Dist 1 Ryegate			Address: PO Box 129, Ryegate MT 59074-0129		
Sys Fac ID 1907975	FITS SITE 36612	Location Name RYEGATE PUBLIC SCHOOLS DIST 1	Location Street Address 207 2ND AVE W PO BOX 129	Location City RYEGATE, MT 59074	Location Phone (406) 568-2211
Operating Permit Renewal Date: 04-Jun-2013			Last inspected on: 15-Apr-2010		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / S2 Currently in Use	1870	8/1/1996 15 / Yes	Diesel 5,000	Asphalt Coated or Bare Steel None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Super D Grocery Inc			Address: 203 E Railway, PO Box 170, Ryegate MT 59074		
Sys Fac ID 1913735	FITS SITE 36621	Location Name SUPER D GROCERY	Location Street Address 203 E RAILWAY AVE	Location City RYEGATE, MT 59074	Location Phone (406) 568-2378
Operating Permit Renewal Date: 10-Dec-2012			Last inspected on: 20-Nov-2009		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1 Currently in Use	3462	4/8/1996 16 / Yes	Gasoline 5,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / S2 Currently In Use	3727	12/1/1998 13 / Yes	Gasoline 8,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / S3 Currently In Use	3728	12/1/1998 13 / Yes	Diesel 4,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed