

## Facility Summary in JEFFERSON County in the City of BOULDER

<b>Owner:</b> Major Brands Distributing Imports Inc			<b>Address:</b> PO Box 6000, Butte MT 59702-6000		
<b>Sys Fac ID</b> 2208673	<b>FITS SITE</b> 37143	<b>Location Name</b> TOWN PUMP INC BOULDER	<b>Location Street Address</b> 703 N MAIN	<b>Location City</b> BOULDER, MT 59632	<b>Location Phone</b> (406) 225-4330
<b>Operating Permit Renewal Date:</b> 29-Jun-2013			<b>Last inspected on:</b> 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 04 Currently in Use	4477	1/1/1989 23 / No	Diesel 12,000	STI-P3 Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
2 / 05 Currently in Use	4478	5/10/1989 22 / No	Diesel 9,000	STI-P3 Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
3 / 02 Currently in Use	2486	5/10/1977 34 / No	Gasoline 6,000	Asphalt Coated or Bare Steel Impressed Current	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
4 / 03 Currently in Use	2487	5/10/1977 34 / No	Gasoline 6,000	Asphalt Coated or Bare Steel Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
5 / 01 Currently in Use	2485	5/10/1977 34 / No	Gasoline 12,000	Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
6 / 06 Currently In Use	4479	4/1/2001 11 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes
7 / 07 Currently In Use	4480	4/1/2001 11 / No	Diesel 5,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H ● K L	Yes Yes Yes

<b>Owner:</b> Harlows School Bus Service Inc			<b>Address:</b> 30772 US Highway 2, Libby MT 59923-3130		
<b>Sys Fac ID</b> 2212378	<b>FITS SITE</b> 37180	<b>Location Name</b> HARLOWS SCHOOL BUS SERVICE INC BOULD	<b>Location Street Address</b> 101 N MAIN ST	<b>Location City</b> BOULDER, MT 59632	<b>Location Phone</b> (406) 225-3344
<b>Operating Permit Renewal Date:</b> 13-Aug-2008			<b>Last inspected on:</b> 26-Aug-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
6 / 06 Temporarily Out of Use	2710	10/1/1991 20 / No	Gasoline 2,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A ● C ● E F G H I J K L ● D E F G H I ● K L	Yes Yes Yes
7 / 07 Temporarily Out of Use	2711	10/1/1991 20 / No	Diesel 2,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A ● C ● E F G H I J K L ● D E F G H I ● K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in JEFFERSON County in the City of CARDWELL

<b>Owner:</b> Kipp Huckaba		<b>Address:</b> PO Box 55, Cardwell MT 59721-0055			
<b>Sys Fac ID</b> 2213424	<b>FITS SITE</b> 37201	<b>Location Name</b> CARDWELL STORE LLC	<b>Location Street Address</b> 770 MT Highway 2 E	<b>Location City</b> CARDWELL, MT 59721	<b>Location Phone</b>
<b>Operating Permit Renewal Date:</b> 03-Sep-2014			<b>Last inspected on:</b> 18-Mar-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Installed Spill/Over/CPMe
							Piping Release Detection	
1 / 01 Currently in Use	3193	4/1/1994 18 / No	Gasoline 9,000	Cathodically Protected Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
2 / 02 Currently in Use	3194	4/1/1994 18 / No	Gasoline 3,000	Cathodically Protected Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
3 / 03 Currently in Use	3195	4/1/1994 18 / No	Diesel 6,000	Cathodically Protected Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
4 / 04 Currently in Use	3196	4/1/1994 18 / No	Diesel 6,000	Cathodically Protected Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in JEFFERSON County in the City of CLANCY

<b>Owner:</b> Montana City Properties Inc			<b>Address:</b> Attn Charles L Hunter, 1 Jackson Creek Rd, Clancy MT 59634-9714		
<b>Sys Fac ID</b> 2201822	<b>FITS SITE</b> 37039	<b>Location Name</b> MONTANA CITY STORE LLC	<b>Location Street Address</b> 1 JACKSON CREEK RD	<b>Location City</b> CLANCY, MT 59634	<b>Location Phone</b> (406) 443-0150
<b>Operating Permit Renewal Date:</b> 01-Jun-2013			<b>Last inspected on:</b> 24-May-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently in Use	1668	7/1/1988 23 / No	Diesel 4,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently in Use	1669	7/1/1988 23 / No	Gasoline 10,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently in Use	1670	7/1/1988 23 / No	Gasoline 10,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

<b>Owner:</b> EMMK LLC			<b>Address:</b> PO Box 316, Clancy MT 59634-0316		
<b>Sys Fac ID</b> 2202898	<b>FITS SITE</b> 37060	<b>Location Name</b> CLANCY STORE UST	<b>Location Street Address</b> 10 E CLANCY ST	<b>Location City</b> CLANCY, MT 59634	<b>Location Phone</b> (406) 933-8278
<b>Operating Permit Renewal Date:</b> 13-Jun-2008			<b>Last inspected on:</b> 09-Oct-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Temporarily Out of Use	3534	4/26/1984 28 / No	Gasoline 2,000	Asphalt Coated or Bare Steel Impressed Current	Bare Steel None	Safe Suction	A B C D E F G H I J K L C D E F G H I J K L	Yes Yes Yes
3 / 03 Temporarily Out of Use	4647	4/10/1993 19 / No	Gasoline 1,000	Asphalt Coated or Bare Steel Impressed Current	Bare Steel None	Safe Suction	A B C D E F G H I J K L C D E F G H I J K L	Yes Yes Yes

<b>Owner:</b> Ash Grove Cement Company			<b>Address:</b> 100 State Highway 518, Clancy MT 59634-9665		
<b>Sys Fac ID</b> 2202928	<b>FITS SITE</b> 37061	<b>Location Name</b> ASH GROVE CEMENT WEST INC	<b>Location Street Address</b> 100 State Highway 518	<b>Location City</b> CLANCY, MT 59634	<b>Location Phone</b> (406) 442-8855
<b>Operating Permit Renewal Date:</b> 08-Dec-2012			<b>Last inspected on:</b> 11-Jun-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
-----------------------------	---------------	----------------------	---------------------	--	-------------------------------------	-------------	--	------------------------------

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

### Facility Summary in JEFFERSON County in the City of CLANCY

4 / 04	<b>392</b>	3/30/1990	Gasoline	STI-P3	Galvanized Steel	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	E	F	G	H	I	J	K	L			
A	B	C	●	E	F	G	H	I	J	K	L																							
●	●	●	●	E	F	G	H	I	J	K	L																							
Currently in Use		22 / No	4,000	None	none							Yes	Yes	Yes																				
5 / 05	<b>393</b>	3/30/1990	Diesel	STI-P3	Galvanized Steel	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	E	F	G	H	I	J	K	L			
A	B	C	●	E	F	G	H	I	J	K	L																							
●	●	●	●	E	F	G	H	I	J	K	L																							
Currently in Use		22 / No	4,000	None	none							Yes	Yes	Yes																				

**Tank/Piping Release Detection Codes**

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed



## Facility Summary in JEFFERSON County in the City of WHITEHALL

8 / 08	2483	1/1/1987	Diesel	STI-P3	Fiberglass Reinforced Plas	Pressurized	A B C ● E F G H ● J K L	Yes	Yes	Yes
Currently in Use		25 / No	12,000	None	None	● E F G H ● J K L				
9 / 09	2484	1/1/1987	Diesel	STI-P3	Flexible Plastic	Pressurized	A B C ● E F G H ● J K L	Yes	Yes	Yes
Currently in Use		25 / No	12,000	None	Double-Walled	● E F ● H ● J K L				
10 / 10	4198	5/1/2000	Diesel	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	A B C ● E F ● H ● J K L	Yes	Yes	Yes
Currently In Use		11 / No	5,000	Double-Walled	Double-Walled	B ● E F ● H ● J K L				
11 / 11	4199	5/1/2000	Diesel	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	A B C ● E F ● H ● J K L	Yes	Yes	Yes
Currently In Use		11 / No	10,000	Double-Walled	Double-Walled	B ● E F ● H ● J K L				

<b>Owner:</b> Golden Sunlight Mines Inc		<b>Address:</b> 453 MT Highway 2 E, Whitehall MT 59759-8637			
<b>Sys Fac ID</b> 2204689	<b>FITS SITE</b> 37091	<b>Location Name</b> GOLDEN SUNLIGHT MINES INC UST	<b>Location Street Address</b> 453 MT HIGHWAY 2 E	<b>Location City</b> WHITEHALL, MT 59759	<b>Location Phone</b> (406) 287-2016
<b>Operating Permit Renewal Date:</b> 17-Dec-2012		<b>Last inspected on:</b> 14-Dec-2009			

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Temporarily Out of Use	5232	4/19/1983 29 / No	Other 3,000	Asphalt Coated or Bare Steel None	Bare Steel None	Pressurized	A B C D E F G H I J K ● B D E F G H I J K ●	No No No
6 / 06 Currently in Use	5218	6/12/2008 03 / Yes	Other 1,000	Not Listed None	Other Double-Walled	Pressurized	A B C D E F G H I J ● L B D E F ● H I J K L	No No No
7 / 07 Currently in Use	5219	6/12/2008 03 / Yes	Other 1,000	Not Listed None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● L B D E F ● H I J K L	No No No
8 / 08 Currently in Use	5220	6/12/2009 02 / Yes	Other 1,500	Not Listed None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● L B D E F ● H I J K L	No No No
9 / 09 Currently in Use	5221	6/12/2008 03 / Yes	Waste Oil 2,000	Not Listed None	Steel - Terminal Piping Double-Walled	Pressurized	A B C D E F G H I J ● L B D E F ● H I J K L	No No No
10 / 10 Currently in Use	5222	6/12/2008 03 / Yes	Other 2,000	Not Listed None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J ● L B D E F ● H I J K L	No No No

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed