

Facility Summary in JUDITH BASIN County in the City of GEYSER

Owner: School Dist 58 Geysler			Address: PO Box 70, Geysler MT 59447-0070		
Sys Fac ID 2303795	FITS SITE 37242	Location Name GEYSER SCHOOL DIST 58	Location Street Address 103 3RD ST E PO BOX 70	Location City GEYSER, MT 59447	Location Phone (406) 735-4368
Operating Permit Renewal Date: 26-Mar-2015			Last inspected on: 07-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently In Use	4609	7/19/1990 21 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C <input checked="" type="radio"/> E F G H I J K L B D E F G H I <input checked="" type="radio"/> K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308977	FITS SITE 37316	Location Name MALMSTROM AFB A 3	Location Street Address US HIGHWAY 87	Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 04-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	223	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308986	FITS SITE 37317	Location Name MALMSTROM AFB B 1	Location Street Address US HIGHWAY 87	Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 19-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 03 Currently in Use	224	5/2/1962 49 / No	Diesel 12,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Flexible Plastic Double-Walled	U.S. Suction	A B C D <input checked="" type="radio"/> F G H I J K L B D <input checked="" type="radio"/> F <input checked="" type="radio"/> H I <input checked="" type="radio"/> K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of GEYSER

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536	
Sys Fac ID 2308992	FITS SITE 37320	Location Name MALMSTROM AFB B 7	Location Street Address US HIGHWAY 87
		Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015		Last inspected on: 04-Oct-2011	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	227	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536	
Sys Fac ID 2308993	FITS SITE 37321	Location Name MALMSTROM AFB B 8	Location Street Address US HIGHWAY 87
		Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015		Last inspected on: 15-Nov-2011	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	228	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536	
Sys Fac ID 2308994	FITS SITE 37322	Location Name MALMSTROM AFB B 9	Location Street Address US HIGHWAY 87
		Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015		Last inspected on: 15-Nov-2011	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	229	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of GEYSER

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308995	FITS SITE 37323	Location Name MALMSTROM AFB B 10	Location Street Address US HIGHWAY 87	Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 15-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	230	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="12" style="text-align: center;">(B) (D) (E) (F) (H) (I) (J) (K) (L)</td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	(B) (D) (E) (F) (H) (I) (J) (K) (L)												Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
(B) (D) (E) (F) (H) (I) (J) (K) (L)																																

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308996	FITS SITE 37324	Location Name MALMSTROM AFB B 11	Location Street Address US HIGHWAY 87	Location City GEYSER, MT 59447	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 04-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	231	6/21/1989 22 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="12" style="text-align: center;">(B) (D) (E) (F) (H) (I) (J) (K) (L)</td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	(B) (D) (E) (F) (H) (I) (J) (K) (L)												Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
(B) (D) (E) (F) (H) (I) (J) (K) (L)																																

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of HOBSON

Owner: School Dist 25 Hobson			Address: PO Box 410, Hobson MT 59452-0410		
Sys Fac ID 2305904	FITS SITE 37277	Location Name HOBSON SCHOOL DIST 25	Location Street Address CENTRAL AVE	Location City HOBSON, MT 59452	Location Phone (406) 423-5483
Operating Permit Renewal Date: 22-Aug-2012			Last inspected on: 20-Apr-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
3 / S3 Currently in Use	1388	8/18/1990 21 / No	Heating Oil 10,000	STI-P3 None	Flexible Plastic Secondary Containment C	U.S. Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="checkbox"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td><input checked="" type="checkbox"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L	B		D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L		Yes Yes Yes
A	B	C	D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L																					
B		D	<input checked="" type="checkbox"/>	F	G	H	I	J	K	L																						

Owner: Woodhall Distributing			Address: PO Box 9, Stanford MT 59479-0009		
Sys Fac ID 2306450	FITS SITE 37283	Location Name WOODHALL DISTRIBUTING	Location Street Address 21 Sawmill Rd	Location City HOBSON, MT 59452	Location Phone (406) 366-0308
Operating Permit Renewal Date: 10-Jul-2014			Last inspected on: 19-Apr-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
5 / 05 Currently In Use	4745	4/1/1998 14 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L		Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																						
6 / 06 Currently In Use	4746	4/1/1998 14 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	B		D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L		Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
B		D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																						

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309104	FITS SITE 37336	Location Name MALMSTROM AFB L 9	Location Street Address ROAD 400	Location City HOBSON, MT 59452	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 25-Aug-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	243	5/1/1993 18 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="checkbox"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="checkbox"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="checkbox"/>	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of HOBSON

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309114	FITS SITE 37337	Location Name MALMSTROM AFB M 8	Location Street Address ROAD 400	Location City HOBSON, MT 59452	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 27-Sep-2010		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Piping Release Detection	Installed Spill/Over/CPMe
1 / 02	244	5/1/1993	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L	A B C D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes
Currently in Use		18 / No	4,000	Double-Walled	Double-Walled		B D E F <input checked="" type="radio"/> H I J K L		

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2309000	FITS SITE 37328	Location Name MALMSTROM AFB C 4	Location Street Address US HIGHWAY 87	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 23-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	235	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2309001	FITS SITE 37329	Location Name MALMSTROM AFB C 5	Location Street Address US HIGHWAY 87	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 22-Jul-2014			Last inspected on: 12-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	236	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2309002	FITS SITE 37330	Location Name MALMSTROM AFB C 6	Location Street Address ROAD 239	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 23-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	237	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Safe Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of MOCCASIN

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309003	FITS SITE 37331	Location Name MALMSTROM AFB C 7	Location Street Address ROAD 239	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 23-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 02 Currently in Use	238	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309115	FITS SITE 37338	Location Name MALMSTROM AFB M 9	Location Street Address US HIGHWAY 87	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 28-Sep-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 02 Currently in Use	245	5/1/1993 18 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309116	FITS SITE 37339	Location Name MALMSTROM AFB M 10	Location Street Address US HIGHWAY 87	Location City MOCCASIN, MT 59462	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 28-Sep-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	246	5/1/1993 18 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2008978	FITS SITE 36684	Location Name MALMSTROM AFB A 4	Location Street Address ROAD 427	Location City RAYNESFORD, MT 59469	Location Phone (406) 731-6163
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 29-Sep-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	221	6/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Mountain View Coop Black Eagle			Address: Attn Pat or Frank, 2200 Old Havre Hwy, Black Eagle MT 59414-1043		
Sys Fac ID 2303301	FITS SITE 37236	Location Name KIBBEY KORNER TRUCK STOP	Location Street Address US HIGHWAY 87 & ROUTE 427 PO BOX 197	Location City RAYNESFORD, MT 59469	Location Phone (406) 738-4400
Operating Permit Renewal Date: 04-Aug-2013			Last inspected on: 21-May-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / S10 Currently in Use	1030	9/1/1996 15 / Yes	Diesel 10,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
5 / S09 Currently in Use	1029	9/1/1996 15 / Yes	Gasoline 10,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
6 / S08 Currently in Use	1028	9/1/1996 15 / Yes	Diesel 8,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
7 / S07 Currently in Use	1027	9/1/1996 15 / Yes	Diesel 8,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
8 / S06 Currently in Use	1026	9/1/1996 15 / Yes	Gasoline 25,000	Asphalt Coated or Bare Steel None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of RAYNESFORD

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308974	FITS SITE 37315	Location Name MALMSTROM AFB A 1	Location Street Address US HIGHWAY 87	Location City RAYNESFORD, MT 59469	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 19-Nov-2010		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01	222	5/2/1962	Diesel	Cathodically Protected Steel	Flexible Plastic	U.S. Suction	<input type="radio"/> A <input type="radio"/> B <input type="radio"/> C <input type="radio"/> D <input checked="" type="radio"/> E <input type="radio"/> F <input type="radio"/> G <input type="radio"/> H <input type="radio"/> I <input type="radio"/> J <input type="radio"/> K <input type="radio"/> L <input type="radio"/> B <input type="radio"/> D <input checked="" type="radio"/> E <input checked="" type="radio"/> F <input checked="" type="radio"/> H <input type="radio"/> I <input checked="" type="radio"/> K <input type="radio"/> L	Yes Yes Yes
Currently in Use		49 / No	12,000	Lined Interior/Impressed Curre	Double-Walled			

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of STANFORD

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 1408988	FITS SITE 34853	Location Name MALMSTROM AFB B 3	Location Street Address MT HIGHWAY 81	Location City STANFORD, MT 59479	Location Phone (406) 731-6167
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 05-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	163	8/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 1408989	FITS SITE 34854	Location Name MALMSTROM AFB B 4	Location Street Address MT HIGHWAY 80	Location City STANFORD, MT 59479	Location Phone (406) 731-6167
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 05-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 02 Currently in Use	164	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Shirley Woodhall			Address: PO Box 485, Stanford MT 59479-0485		
Sys Fac ID 2301526	FITS SITE 37220	Location Name BY WAY SERVICE STATION	Location Street Address MT HIGHWAY 80 & US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone (406) 566-2203
Operating Permit Renewal Date: 23-Oct-2014			Last inspected on: 15-Sep-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 06 Currently in Use	4410	9/1/1996 15 / No	Diesel 5,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	4411	10/1/1998 13 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L D E F G H I J K L	Yes Yes Yes
8 / 08 Currently In Use	4412	10/1/1998 13 / No	Gasoline 5,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L C D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of STANFORD

Owner: School Dist 12 Stanford			Address: PO Box 506, Stanford MT 59479-0506		
Sys Fac ID 2301938	FITS SITE 37225	Location Name STANFORD SCHOOL DIST 12	Location Street Address 104 4TH AVE S	Location City STANFORD, MT 59479	Location Phone (406) 566-2265
Operating Permit Renewal Date: 11-Oct-2013			Last inspected on: 09-Sep-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / S3 Currently In Use	1893	10/9/1998 13 / No	Heating Oil 8,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G <input checked="" type="radio"/> H I J K L B D E F G <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: Woodhall Distributing			Address: PO Box 1018, Denton MT 59430-1018		
Sys Fac ID 2303303	FITS SITE 37237	Location Name WOODHALL DISTRIBUTING	Location Street Address MT HIGHWAY 80 & MAIN ST	Location City STANFORD, MT 59479	Location Phone (406) 566-2671
Operating Permit Renewal Date: 04-Aug-2013			Last inspected on: 09-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently In Use	1031	7/6/1998 13 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C D <input checked="" type="radio"/> E F G H I J K L B D E F G H I J <input checked="" type="radio"/> K L	Yes Yes Yes
5 / 05 Currently In Use	1032	7/6/1998 13 / No	Gasoline 2,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Safe Suction	A B C D <input checked="" type="radio"/> E F G H I J K L B D E F G H I J <input checked="" type="radio"/> K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308987	FITS SITE 37318	Location Name MALMSTROM AFB B 2	Location Street Address MT HIGHWAY 80	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 05-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently In Use	225	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> G H I J K L B D E F <input checked="" type="radio"/> G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of STANFORD

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2308991	FITS SITE 37319	Location Name MALMSTROM AFB B 6	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 04-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	226	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2308997	FITS SITE 37325	Location Name MALMSTROM AFB C 1	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone (406) 731-3247
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 19-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	232	5/2/1962 49 / No	Diesel 12,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Flexible Plastic Double-Walled	U.S. Suction	A B C D <input checked="" type="radio"/> F G H I J K L B D <input checked="" type="radio"/> F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536			
Sys Fac ID 2308998	FITS SITE 37326	Location Name MALMSTROM AFB C 2	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 21-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	233	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of STANFORD

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2308999	FITS SITE 37327	Location Name MALMSTROM AFB C 3	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 21-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	234	9/11/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309004	FITS SITE 37332	Location Name MALMSTROM AFB C 8	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 22-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 02 Currently in Use	239	9/11/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Safe Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309005	FITS SITE 37333	Location Name MALMSTROM AFB C 9	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 22-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 02 Currently in Use	240	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	<table border="1" style="font-size: small;"> <tr> <td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td> </tr> <tr> <td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td> </tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in JUDITH BASIN County in the City of STANFORD

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309006	FITS SITE 37334	Location Name MALMSTROM AFB C 10	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 08-Jul-2014			Last inspected on: 22-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	241	9/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2309007	FITS SITE 37335	Location Name MALMSTROM AFB C 11	Location Street Address US HIGHWAY 87	Location City STANFORD, MT 59479	Location Phone
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 12-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	242	10/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2608990	FITS SITE 38613	Location Name MALMSTROM AFB B 5	Location Street Address MT HIGHWAY 80	Location City STANFORD, MT 59479	Location Phone (406) 731-6167
Operating Permit Renewal Date: 06-Apr-2015			Last inspected on: 05-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	258	9/10/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Safe Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed