

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Owner: Ben E Arps Exxon			Address: PO Box 58, Augusta MT 59410-0058		
Sys Fac ID 2502114	FITS SITE 38007	Location Name AUGUSTA SERVICE STATION LLP	Location Street Address MAIN ST	Location City AUGUSTA, MT 59410	Location Phone (406) 562-3377
Operating Permit Renewal Date: 22-Aug-2014			Last inspected on: 06-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 06 Currently in Use	3950	6/6/1989 22 / No	Diesel 1,500	Composite (Steel w/ FRP) None	Fiberglass Reinforced Plas none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 05 Currently in Use	3951	6/6/1989 22 / No	Gasoline 750	Composite (Steel w/ FRP) None	Fiberglass Reinforced Plas none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 04 Currently in Use	3952	6/6/1989 22 / No	Gasoline 750	Composite (Steel w/ FRP) None	Fiberglass Reinforced Plas none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2509034	FITS SITE 38353	Location Name MALMSTROM AFB F 5	Location Street Address MT HIGHWAY 21	Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 19-Dec-2014			Last inspected on: 29-Aug-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	247	5/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2509035	FITS SITE 38354	Location Name MALMSTROM AFB F 6	Location Street Address US HIGHWAY 287	Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 19-Dec-2014			Last inspected on: 29-Aug-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	248	5/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2509036	FITS SITE 38355	Location Name MALMSTROM AFB F 7	Location Street Address ROAD 434	Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 08-Mar-2015			Last inspected on: 29-Aug-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	249	6/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2509049	FITS SITE 38360	Location Name MALMSTROM AFB G 9	Location Street Address US HIGHWAY 287	Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	254	10/1/1991 20 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: 341 CES CEANQ			Address: 39 78th St N, Malmstrom AFB MT 59402-7536		
Sys Fac ID 2509050	FITS SITE 38361	Location Name MALMSTROM AFB G 10	Location Street Address US HIGHWAY 287	Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 01-Mar-2014			Last inspected on: 18-Nov-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	255	6/1/1992 19 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of AUGUSTA

Owner: 341 CES CEANQ		Address: 39 78th St N, Malmstrom AFB MT 59402-7536	
Sys Fac ID 5009030	FITS SITE 43422	Location Name MALMSTROM AFB F 1	Location Street Address US HIGHWAY 287
		Location City AUGUSTA, MT 59410	Location Phone
Operating Permit Renewal Date: 01-Mar-2014		Last inspected on: 19-Nov-2010	

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01	303	6/2/1962	Diesel	Cathodically Protected Steel	Flexible Plastic	U.S. Suction	<input type="radio"/> A <input type="radio"/> B <input type="radio"/> C <input type="radio"/> D <input checked="" type="radio"/> E <input type="radio"/> F <input type="radio"/> G <input type="radio"/> H <input type="radio"/> I <input type="radio"/> J <input type="radio"/> K <input type="radio"/> L	Yes Yes Yes
Currently in Use		49 / No	12,000	Lined Interior/Impressed Curre	Double-Walled		<input type="radio"/> B <input type="radio"/> D <input checked="" type="radio"/> E <input checked="" type="radio"/> F <input checked="" type="radio"/> H <input type="radio"/> I <input checked="" type="radio"/> K <input type="radio"/> L	

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Owner: Big Sky Food and Fuel Inc			Address: Rober J Merzlake, 3012 Canyon Ferry Rd, East Helena MT 59635-3025		
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone
2503122	38056	CANYON FERRY MINI BASKET	3012 CANYON FERRY RD	EAST HELENA, MT 59635	(406) 227-8506
Operating Permit Renewal Date: 30-Mar-2013			Last inspected on: 23-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	2319	6/1/1994 17 / No	Gasoline 10,000	Cathodically Protected Steel None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
4 / 04 Currently in Use	5151	10/16/2007 04 / No	Diesel 5,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently in Use	5152	10/16/2007 04 / No	Gasoline 6,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Town Pump of East Helena Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone
2508697	38336	TOWN PUMP INC EAST HELENA	418 W MAIN ST	EAST HELENA, MT 59635	
Operating Permit Renewal Date: 29-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4672	4/14/1968 44 / No	Gasoline 12,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
2 / 02 Currently in Use	4673	4/14/1968 44 / No	Gasoline 12,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
3 / 03 Currently in Use	4674	4/14/1968 44 / No	Diesel 8,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
4 / 04 Currently in Use	4675	4/14/1968 44 / No	Diesel 3,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
5 / 05 Currently in Use	4676	4/14/1968 44 / No	Gasoline 4,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
6 / 06 Currently in Use	4677	4/14/1977 35 / No	Gasoline 6,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes
7 / 07 Currently in Use	4678	4/14/1977 35 / No	Gasoline 6,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H ● ● K L B ● E F G H ● ● K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of EAST HELENA

Owner: Miles City Holdings LLC		Address: PO Box 6000, Butte MT 59702-6000			
Sys Fac ID 5613915	FITS SITE 45130	Location Name TOWN PUMP OF EAST HELENA #2	Location Street Address 116 LANE AVE	Location City EAST HELENA, MT 59635	Location Phone (406) 227-9170
Operating Permit Renewal Date: 29-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Installed Spill/Over/CPMe
							Piping Release Detection	
1 / 01 Currently In Use	4028	12/1/1998 13 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently In Use	4029	12/1/1998 13 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently In Use	4030	12/1/1998 13 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently In Use	4031	12/1/1998 13 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
5 / 05 Currently In Use	4032	12/1/1998 13 / No	Diesel 6,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4033	3/1/1999 13 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	4861	8/18/2003 08 / No	Diesel 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of Fort Harrison

Owner: US Dept of Veterans Affairs			Address: Fort Harrison, 3687 Veterans Drive, Fort Harrison MT 59636		
Sys Fac ID 2505908	FITS SITE 38201	Location Name VETERANS HEALTH ADMINISTRATION	Location Street Address WILLIAMS ST & BIRDSEYE RD 3687 Veterans Drive Bldg 141	Location City Fort Harrison, MT 59636	Location Phone (406) 447-7382
Operating Permit Renewal Date: 03-Feb-2015			Last inspected on: 23-Sep-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe
							Piping Release Detection		
1 / 09 Currently in Use	2215	11/30/1993 18 / No	Diesel 2,500	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	
3 / 08 Currently in Use	2214	12/1/1993 18 / No	Gasoline 1,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	
7 / 10 Currently in Use	2216	12/1/1993 18 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	
8 / 11 Currently in Use	2217	12/1/1993 18 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	
9 / 12 Currently in Use	2218	12/1/1993 18 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	
13 / 13 Currently in Use	5278	10/1/2010 01 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes	

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Exec Air Montana Inc			Address: 2560 Airport Rd, Helena MT 59601-1207		
Sys Fac ID 2500642	FITS SITE 37927	Location Name EXEC AIR MONTANA INC 1	Location Street Address 2430 AIRPORT RD	Location City HELENA, MT 59601	Location Phone
Operating Permit Renewal Date: 23-Oct-2013			Last inspected on: 18-Jun-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently in Use	3344	6/1/1991 20 / No	Other 12,000	STI-P3 Double-Walled	No Piping None	Gravity Feed	A B C D E F <input checked="" type="radio"/> H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently in Use	3345	6/1/1991 20 / No	Other 12,000	STI-P3 Double-Walled	No Piping None	Pressurized	A B C D E F <input checked="" type="radio"/> H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Lewis & Clark County Jail			Address: 228 E Broadway St Rm 5, Helena MT 59601-4263		
Sys Fac ID 2500945	FITS SITE 37940	Location Name COMBINED CRIMINAL JUSTICE FACILITY	Location Street Address 221 BRECKENRIDGE ST	Location City HELENA, MT 59601	Location Phone (406) 447-8299
Operating Permit Renewal Date: 31-Oct-2013			Last inspected on: 05-Oct-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4060	4/21/1985 27 / No	Diesel 3,000	STI-P3 None	Flexible Plastic Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Owner: Greg Axtman			Address: 3980 Lake Hills Ln, Helena MT 59602-8503		
Sys Fac ID 2501091	FITS SITE 37946	Location Name KIMS MARINA & RESORT	Location Street Address 8015 CANYON FERRY RD	Location City HELENA, MT 59602	Location Phone
Operating Permit Renewal Date: 10-May-2014			Last inspected on: 08-Mar-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently in Use	3516	5/1/1993 18 / No	Gasoline 3,782	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C <input checked="" type="radio"/> E F <input checked="" type="radio"/> H I J K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Northwestern Energy			Address: 40 E Broadway St, Butte MT 59701-9394		
Sys Fac ID 2501183	FITS SITE 37950	Location Name HELENA SERVICE CENTER	Location Street Address 1315 N Last Chance Gulch	Location City HELENA, MT 59601	Location Phone (406) 467-2669
Operating Permit Renewal Date: 12-Aug-2014			Last inspected on: 09-Mar-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently In Use	1678	5/1/1998 13 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently In Use	1679	5/1/1998 13 / No	Diesel 4,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Associated Food Stores Inc Helena			Address: PO Box 4069, Helena MT 59604-4069		
Sys Fac ID 2501273	FITS SITE 37951	Location Name ASSOCIATED FOOD STORES INC HELENA	Location Street Address 2705 AIRPORT RD	Location City HELENA, MT 59601	Location Phone (406) 442-3140
Operating Permit Renewal Date: 16-Nov-2013			Last inspected on: 18-Sep-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
7 / 07 Currently In Use	4534	5/18/2001 10 / No	Diesel 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
8 / 08 Currently In Use	4535	5/18/2001 10 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Barbara Leland			Address: 1831 11th Ave, Helena MT 59601-4769		
Sys Fac ID 2501314	FITS SITE 37953	Location Name FRIENDLYS SINCLAIR	Location Street Address 1831 11TH AVE	Location City HELENA, MT 59601	Location Phone (406) 442-4865
Operating Permit Renewal Date: 26-Jul-2014			Last inspected on: 27-Jan-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently In Use	4611	1/2/2002 10 / No	Diesel 6,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

6 / 06	4612	1/2/2002	Gasoline	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="radio"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes	Yes	Yes
A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L																							
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																								
Currently In Use		10 / No	12,000	None	Double-Walled																													
7 / 07	4613	1/2/2002	Gasoline	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="radio"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes	Yes	Yes
A	B	C	<input checked="" type="radio"/>	E	F	G	H	I	J	K	L																							
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																								
Currently In Use		10 / No	20,000	None	Double-Walled																													

Owner: Conoco Phillips Company				Address: 2626 Lillian Avenue, Billings MT 59101-1922			
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone		
2501846	37990	CONOCO PHILLIPS HELENA TERMINAL	3180 E US Highway 12 PO BOX 30198	HELENA, MT 59601	(406) 442-6395		
Operating Permit Renewal Date: 28-May-2013				Last inspected on: 25-Feb-2010			

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
2 / 39	4919	1/1/1993	Mixture	Fiberglass Reinforced Plastic	Bare Steel	Gravity Feed	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td><input checked="" type="radio"/></td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes Yes Yes
A	B	C	D	E	F	<input checked="" type="radio"/>	H	I	J	K	L																					
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																						
Currently in Use		19 / No	10,000	Double-Walled	None																											

Owner: Exec Air Montana Inc				Address: 2560 Airport Rd, Helena MT 59601-1207			
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone		
2502123	38009	EXEC AIR MONTANA INC 2	2430 AIRPORT RD	HELENA, MT 59601	(406) 442-2190		
Operating Permit Renewal Date: 17-Dec-2013				Last inspected on: 18-Jun-2010			

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 01	3646	4/1/1966	Jet Fuel	Asphalt Coated or Bare Steel	No Piping	Not Listed	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="radio"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes Yes Yes
A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L																					
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																						
Currently in Use		46 / No	15,000	Impressed Current	None																											
2 / 02	3647	4/1/1966	Jet Fuel	Asphalt Coated or Bare Steel	No Piping	Not Listed	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="radio"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes Yes Yes
A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L																					
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																						
Currently in Use		46 / No	15,000	Impressed Current	None																											
3 / 03	3648	4/1/1966	Gasoline	Asphalt Coated or Bare Steel	No Piping	Not Listed	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="radio"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes Yes Yes
A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L																					
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																						
Currently in Use		46 / No	15,000	Impressed Current	None																											
4 / 04	3649	4/1/1966	Gasoline	Asphalt Coated or Bare Steel	No Piping	Not Listed	<table border="1" style="font-size: 8px; border-collapse: collapse;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td><input checked="" type="radio"/></td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td><td colspan="2"><input checked="" type="radio"/></td></tr> </table>	A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L	B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		Yes Yes Yes
A	B	C	D	<input checked="" type="radio"/>	F	G	H	I	J	K	L																					
B		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>		<input checked="" type="radio"/>																						
Currently in Use		46 / No	15,000	Impressed Current	None																											

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Tray LLC			Address: 1701 Cedar St, Helena MT 59601-1109		
Sys Fac ID 2503466	FITS SITE 38076	Location Name GABES CONVENIENCE STORE	Location Street Address 1701 CEDAR ST	Location City HELENA, MT 59601	Location Phone (406) 443-3760
Operating Permit Renewal Date: 11-Jun-2015			Last inspected on: 30-Mar-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently In Use	2228	9/1/1998 13 / No	Gasoline 15,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
6 / 06 Currently In Use	2229	9/1/1998 13 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes
7 / 07 Currently In Use	2230	9/1/1998 13 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I J K L	Yes Yes Yes

Owner: United Parcel Service, Inc			Address: 4455 7th Avenue S, Seattle WA 98108		
Sys Fac ID 2504538	FITS SITE 38129	Location Name UNITED PARCEL SERVICE HELENA	Location Street Address 3029 AIRPORT RD	Location City HELENA, MT 59601	Location Phone (406) 449-3505
Operating Permit Renewal Date: 01-Jun-2013			Last inspected on: 16-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently in Use	4446	12/1/1993 18 / No	Diesel 12,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Stockton Oil Company			Address: PO Box 1756, Billings MT 59103-1756		
Sys Fac ID 2504966	FITS SITE 38145	Location Name JOLLY OS GAS N GO	Location Street Address 1200 CEDAR ST	Location City HELENA, MT 59601	Location Phone (406) 442-5621
Operating Permit Renewal Date: 01-Apr-2009			Last inspected on: 12-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Temporarily Out of Use	4784	3/26/1985 27 / No	Gasoline 8,000	STI-P3 None	Galvanized Steel none	Pressurized	A B C D E F G H I J K L ● ● E F G H ● J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

2 / 02	4785	3/26/1985	Gasoline	STI-P3	Galvanized Steel	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes	Yes	Yes
A	B	C	D	E	F	G	H	I	J	K	L																							
●	●	●	●	●	●	●	●	●	●	●	●																							
Temporarily Out of Use		27 / No	8,000	None	none																													
4 / 04	4786	9/1/1991	Gasoline	STI-P3	Fiberglass Reinforced Plas	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes	Yes	Yes
A	B	C	D	E	F	G	H	I	J	K	L																							
●	●	●	●	●	●	●	●	●	●	●	●																							
Temporarily Out of Use		20 / No	4,000	None	None																													

Owner: Jerold Fetters				Address: 1901 N Last Chance Gulch, Helena MT 59601-0742			
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone		
2505099	38149	JERRYS HIWAY SERVICE	1901 N Last Chance Gulch	HELENA, MT 59601	(406) 442-5087		
Operating Permit Renewal Date: 31-Oct-2013				Last inspected on: 16-Oct-2010			

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 01 Currently in Use	1053	11/22/1972 39 / No	Gasoline 8,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					
2 / 02 Currently in Use	4419	11/22/1972 39 / No	Diesel 10,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					
3 / 03 Currently in Use	1055	11/22/1972 39 / No	Gasoline 10,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					

Owner: JTA Inc				Address: 3300 Green Meadow Dr, Helena MT 59602-7707			
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone		
2505688	38193	GREEN MEADOW MARKET	3300 GREEN MEADOW DR	HELENA, MT 59602	(406) 442-7095		
Operating Permit Renewal Date: 13-Aug-2013				Last inspected on: 26-Jul-2010			

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
1 / 01 Currently in Use	3243	10/1/1979 32 / No	Gasoline 8,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					
2 / 02 Currently in Use	3244	10/1/1979 32 / No	Gasoline 10,000	Cathodically Protected Steel Lined Interior/Impressed Curre	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					
3 / 03 Currently in Use	5135	8/8/2007 04 / No	Diesel 8,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					
4 / 04 Currently in Use	5136	8/8/2007 04 / No	Diesel 7,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td><td>●</td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	●	●	●	●	●	●	●	●	●	●	●	●	Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
●	●	●	●	●	●	●	●	●	●	●	●																					

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: CHS Inc			Address: 16124 E Marietta Lane, Spokane Valley WA 99216		
Sys Fac ID 2505774	FITS SITE 38197	Location Name ZIP TRIP 43	Location Street Address 1318 EUCLID AVE	Location City HELENA, MT 59601	Location Phone (406) 442-9402
Operating Permit Renewal Date: 13-Mar-2015			Last inspected on: 03-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 03 Currently in Use	4518	4/26/1984 28 / No	Gasoline 6,000	Asphalt Coated or Bare Steel Impressed Current	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
2 / 01 Currently in Use	4519	4/26/1983 29 / No	Gasoline 10,000	Asphalt Coated or Bare Steel Impressed Current	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
4 / 04 Currently In Use	4520	4/23/1997 15 / No	Gasoline 8,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

Owner: Gates of The Mountains Inc			Address: PO Box 4478, Helena MT 59604-4478		
Sys Fac ID 2506619	FITS SITE 38242	Location Name GATES OF THE MOUNTAINS INC	Location Street Address PO Box 4478	Location City HELENA, MT 59604	Location Phone (406) 458-5241
Operating Permit Renewal Date: 30-Apr-2013			Last inspected on: 21-Oct-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / 03 Currently in Use	1202	4/29/1986 25 / No	Gasoline 5,000	STI-P3 Double-Walled	Galvanized Steel None	Pressurized	A B C D E F G H I J K ● ● ● E F G H I J K L	Yes Yes Yes
4 / 04 Currently in Use	1203	4/29/1986 25 / No	Diesel 1,000	STI-P3 Double-Walled	Galvanized Steel None	Pressurized	A B C D E F G H I J K ● ● ● E F G H I J K L	Yes Yes Yes

Owner: MDOT Helena			Address: Larry Murolo, PO Box 201001, Helena MT 59620-1001		
Sys Fac ID 2506849	FITS SITE 38260	Location Name MDOT HELENA HEADQUARTERS	Location Street Address 2701 PROSPECT AVE	Location City HELENA, MT 59601	Location Phone (406) 444-6163
Operating Permit Renewal Date: 19-Nov-2014			Last inspected on: 11-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
-----------------------------	---------------	----------------------	---------------------	--	-------------------------------------	-------------	--	------------------------------

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

4 / 04	2911	3/1/1996	Diesel	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	●	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes	Yes	Yes
A	B	C	●	E	F	●	H	I	J	K	L																							
B		D	E	F	●	H	I	J	K	L																								
Currently In Use		16 / No	12,000	Double-Walled	Double-Walled																													
5 / 05	2912	3/1/1996	Gasoline	Fiberglass Reinforced Plastic	Flexible Plastic	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	●	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes	Yes	Yes
A	B	C	●	E	F	●	H	I	J	K	L																							
B		D	E	F	●	H	I	J	K	L																								
Currently In Use		16 / No	12,000	Double-Walled	Double-Walled																													

Owner: L&B LLP			Address: 3487 Birkland Dr, Helena MT 59602-9196		
Sys Fac ID 2507353	FITS SITE 38276	Location Name SOUTHS COUNTRY STORE	Location Street Address 3105 YORK RD	Location City HELENA, MT 59602	Location Phone (406) 227-5757
Operating Permit Renewal Date: 23-Sep-2013			Last inspected on: 18-Sep-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
3 / 05 Currently in Use	3562	5/1/1993 18 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●		E	F	G	H	I	J	K	L			Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
●		E	F	G	H	I	J	K	L																							
4 / 06 Currently in Use	3563	5/1/1993 18 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td><td></td></tr> </table>	A	B	C	D	E	F	G	H	I	J	K	L	●		E	F	G	H	I	J	K	L			Yes Yes Yes
A	B	C	D	E	F	G	H	I	J	K	L																					
●		E	F	G	H	I	J	K	L																							

Owner: Bobs Valley Service Inc			Address: 7507 N Montana Ave, Helena MT 59602-9389		
Sys Fac ID 2507404	FITS SITE 38279	Location Name BOBS VALLEY SERVICE INC UST	Location Street Address 7507 N MONTANA AVE	Location City HELENA, MT 59602	Location Phone (406) 458-5140
Operating Permit Renewal Date: 26-Mar-2015			Last inspected on: 02-Feb-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe																								
4 / 05 Temporarily Out of Use	474	3/27/1988 24 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
B		D	E	F	●	H	I	J	K	L																						
5 / 06 Currently in Use	475	3/27/1988 24 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
B		D	E	F	●	H	I	J	K	L																						
6 / 07 Currently in Use	476	6/1/1992 19 / No	Diesel 8,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
B		D	E	F	●	H	I	J	K	L																						
7 / 08 Currently In Use	477	11/15/1998 13 / No	Gasoline 20,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	<table border="1" style="font-size: 8px; text-align: center;"> <tr><td>A</td><td>B</td><td>C</td><td>●</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td colspan="2">B</td><td>D</td><td>E</td><td>F</td><td>●</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td><td></td></tr> </table>	A	B	C	●	E	F	G	H	I	J	K	L	B		D	E	F	●	H	I	J	K	L		Yes Yes Yes
A	B	C	●	E	F	G	H	I	J	K	L																					
B		D	E	F	●	H	I	J	K	L																						

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Rocky Mountain Oil Co Inc			Address: PO Box 1224, Minneapolis MN 55440-1224		
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone
2508067	38311	HOLIDAY STATIONSTORE 270	401 EUCLID AVE	HELENA, MT 59601	(406) 443-0135
Operating Permit Renewal Date: 09-Sep-2014			Last inspected on: 14-Mar-2011		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	3017	5/1/1987 24 / No	Gasoline 12,000	STI-P3 Impressed Current	Bare Steel none	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
2 / 02 Currently in Use	3018	5/1/1987 24 / No	Diesel 10,000	STI-P3 Impressed Current	Bare Steel none	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
3 / 03 Currently in Use	3019	11/1/1987 24 / No	Gasoline 10,000	STI-P3 Impressed Current	Bare Steel none	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
4 / 04 Currently in Use	3020	11/1/1987 24 / No	Gasoline 10,000	STI-P3 Impressed Current	Bare Steel none	Pressurized	A B C D E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

Owner: Monroes High Country Travel Plaza LLC			Address: 3122 E US Highway 12, Helena MT 59601-9701		
Sys Fac ID	FITS SITE	Location Name	Location Street Address	Location City	Location Phone
2508659	38335	MONROE'S HIGH COUNTRY TRAVEL PLAZA	3122 E US Highway 12	HELENA, MT 59601	(406) 442-3259
Operating Permit Renewal Date: 15-Mar-2014			Last inspected on: 24-Feb-2011		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 07 Currently in Use	4526	6/19/1990 21 / No	Diesel 10,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
2 / 06 Currently in Use	4527	6/19/1990 21 / No	Diesel 10,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
8 / 12 Currently in Use	4528	10/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
9 / 13 Currently in Use	4529	10/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
10 / 14 Currently in Use	4530	10/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
11 / 15 Currently in Use	4531	10/1/1996 15 / No	Diesel 15,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Town Pump of Helena Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 2508706	FITS SITE 38337	Location Name TOWN PUMP INC HELENA 1	Location Street Address 1240 Prospect Ave	Location City HELENA, MT 59601	Location Phone
Operating Permit Renewal Date: 29-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	2506	4/15/1983 29 / No	Gasoline 12,000	STI-P3 Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently in Use	2507	4/15/1983 29 / No	Gasoline 12,000	STI-P3 Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently in Use	2508	4/15/1983 29 / No	Gasoline 12,000	STI-P3 Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	2509	11/1/1998 13 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
8 / 08 Currently In Use	2510	11/1/1998 13 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Town Pump of Helena Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 2508707	FITS SITE 38338	Location Name TOWN PUMP INC HELENA 2	Location Street Address 1140 EUCLID AVE	Location City HELENA, MT 59601	Location Phone
Operating Permit Renewal Date: 29-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / 03 Currently in Use	4832	4/14/1984 28 / No	Diesel 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently in Use	4833	7/1/1991 20 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
5 / 05 Currently in Use	4834	7/1/1991 20 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently in Use	4835	7/1/1991 20 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Exxon Company USA Helena			Address: PO Box 4849, Helena MT 59604-4849		
Sys Fac ID 2508728	FITS SITE 38340	Location Name EXXON MARKETING HELENA TERMINAL	Location Street Address 3120 E US Highway 12	Location City HELENA, MT 59601	Location Phone (406) 442-4190
Operating Permit Renewal Date: 25-May-2013			Last inspected on: 18-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
10 / S07 Currently in Use	2774	1/1/1950 62 / Yes	Diesel 638,000	Asphalt Coated or Bare Steel Impressed Current	Steel - Terminal Piping None	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
12 / S05 Currently in Use	2772	1/1/1950 62 / Yes	Gasoline 1,200,000	Asphalt Coated or Bare Steel Impressed Current	Steel - Terminal Piping None	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
14 / S03 Currently in Use	2770	1/1/1950 62 / Yes	Gasoline 604,000	Asphalt Coated or Bare Steel Impressed Current	Steel - Terminal Piping None	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
16 / S01 Currently in Use	2768	1/1/1950 62 / Yes	Gasoline 603,330	Asphalt Coated or Bare Steel Impressed Current	Steel - Terminal Piping None	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
26 / S21 Currently in Use	2786	1/1/1987 25 / Yes	Hazardous S 1,000	Asphalt Coated or Bare Steel Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
28 / S18 Currently in Use	2783	1/1/1987 25 / Yes	Hazardous S 3,000	Asphalt Coated or Bare Steel Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
30 / S15 Currently in Use	2780	1/1/1987 25 / Yes	Hazardous S 10,000	Asphalt Coated or Bare Steel Impressed Current	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
32 / 14 Currently in Use	2767	1/1/1987 25 / No	Mixture 2,000	Cathodically Protected Steel Double-Walled	Bare Steel none	Gravity Feed	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes
35 / S11 Currently in Use	2778	1/1/1950 62 / Yes	Diesel 633,000	Asphalt Coated or Bare Steel Impressed Current	Steel - Terminal Piping None	Pressurized	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes

Owner: Qwest Corporation dba CenturyLink			Address: 250 East 200 South #1601, Salt Lake City UT 84111		
Sys Fac ID 2508775	FITS SITE 38341	Location Name HELENA MAIN CENTRAL OFFICE	Location Street Address 441 N PARK AVE	Location City HELENA, MT 59601	Location Phone (801) 237-5334
Operating Permit Renewal Date: 18-Oct-2014			Last inspected on: 11-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 02 Currently in Use	1728	1/1/1992 20 / Yes	Diesel 2,500	Fiberglass Reinforced Plastic Double-Walled	Bare Steel Double-Walled	U.S. Suction	A B C D E F G H I J K L ● D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Federal Reserve Bank			Address: 100 Neill Ave, Helena MT 59601-3329		
Sys Fac ID 2511291	FITS SITE 38406	Location Name FEDERAL RESERVE BANK HELENA	Location Street Address 100 NEILL AVE	Location City HELENA, MT 59601	Location Phone (406) 447-3946
Operating Permit Renewal Date: 09-Jan-2015			Last inspected on: 21-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1 Currently in Use	2322	10/1/1989 22 / No	Heating Oil 4,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B ● E F ● H I ● K L	Yes Yes Yes

Owner: CHS Inc			Address: 16124 E Marietta Lane, Spokane Valley WA 99216		
Sys Fac ID 2512353	FITS SITE 38434	Location Name ZIP TRIP 42	Location Street Address 3100 N MONTANA AVE	Location City HELENA, MT 59602	Location Phone (406) 449-8766
Operating Permit Renewal Date: 02-Mar-2015			Last inspected on: 03-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 03 Currently in Use	561	6/7/1991 20 / No	Diesel 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
2 / 01 Currently in Use	559	6/7/1991 20 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
3 / 02 Currently in Use	560	6/7/1991 20 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

Owner: Ted Beck			Address: PO Box 4327, Helena MT 59604-4327		
Sys Fac ID 2512834	FITS SITE 38450	Location Name BECKS HELENA U-PUMP INC	Location Street Address 3122 Airport Road	Location City HELENA, MT 59601	Location Phone (406) 443-3518
Operating Permit Renewal Date: 19-Aug-2014			Last inspected on: 10-May-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4444	9/1/1992 19 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L ● ● E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Watkins & Shepard Trucking			Address: PO Box 5328, Missoula MT 59806-5328		
Sys Fac ID 2512917	FITS SITE 38460	Location Name WATKINS & SHEPARD TRUCKING HELENA	Location Street Address 1500 BLAINE ST	Location City HELENA, MT 59601	Location Phone (406) 442-9536
Operating Permit Renewal Date: 18-Jul-2014			Last inspected on: 26-May-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	4458	2/3/1993 19 / No	Waste Oil 2,000	STI-P3 Double-Walled	Bare Steel Double-Walled	Gravity Feed	A B C ● E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes
2 / 02 Currently in Use	4459	2/3/1993 19 / No	Waste Oil 500	STI-P3 Double-Walled	Bare Steel Double-Walled	Gravity Feed	A B C ● E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes
3 / 03 Currently in Use	4460	11/1/1995 16 / No	Diesel 12,000	Composite (Steel w/ FRP) Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C ● E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Juniper Hill Farm LLC			Address: 111 N Last Chance Gulch Ste 3B, Helena MT 59601-4144		
Sys Fac ID 2513657	FITS SITE 38495	Location Name LAKESIDE GENERAL STORE	Location Street Address 5330 YORK RD	Location City HELENA, MT 59602	Location Phone (406) 443-1040
Operating Permit Renewal Date: 30-Mar-2015			Last inspected on: 02-Feb-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 02 Currently in Use	4552	7/24/1995 16 / No	Gasoline 5,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes
2 / 01 Currently in Use	4553	7/1/1995 16 / No	Diesel 8,000	Fiberglass Reinforced Plastic None	Fiberglass Reinforced Plas None	Pressurized	A ● ● ● E F G H I J K L ● ● E F G H I J K L	Yes Yes Yes

Owner: James B Stanger			Address: 3401 Highway 12 E, , Helena MT 59604		
Sys Fac ID 2513687	FITS SITE 38497	Location Name HELENA AUTO CENTER LLC.	Location Street Address 3401 E US Highway 12	Location City HELENA, MT 59601	Location Phone
Operating Permit Renewal Date: 28-Aug-2014			Last inspected on: 25-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
-----------------------------	---------------	----------------------	---------------------	--	-------------------------------------	-------------	--	------------------------------

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

1 / 01 1244 3/15/1996 Waste Oil STI-P3 Bare Steel U.S. Suction A B C D E F G H I J K L
 Currently in Use 16 / No 8,000 Double-Walled Secondary Containment C B D E F G H I J K L Yes Yes No

Owner: Sleeping Giant Pizza LLC		Address: 3425 E US Highway 12, Helena MT 59601-9708	
Sys Fac ID 2513763	FITS SITE 38503	Location Name CENEX EZ STOP EAST	Location Street Address 3425 E US Highway 12
		Location City HELENA, MT 59601	Location Phone (406) 449-4488
Operating Permit Renewal Date: 13-Aug-2013		Last inspected on: 13-Aug-2010	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	365	10/1/1996 15 / No	Gasoline 8,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
2 / 02 Currently in Use	366	10/1/1996 15 / No	Diesel 5,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
3 / 03 Currently in Use	4333	10/1/1996 15 / No	Gasoline 8,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
4 / 04 Currently in Use	368	10/1/1996 15 / No	Diesel 5,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input checked="" type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes

Owner: Park Street Holdings LLC		Address: PO BOX 6000, Butte MT 59702-6000	
Sys Fac ID 5613818	FITS SITE 45050	Location Name TOWN PUMP INC HELENA 6	Location Street Address 2401 N MONTANA AVE
		Location City HELENA, MT 59601	Location Phone (406) 443-5068
Operating Permit Renewal Date: 29-Jun-2013		Last inspected on: 22-Feb-2010	

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	4610	9/1/1997 14 / No	Gasoline 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input checked="" type="checkbox"/> I <input checked="" type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input checked="" type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes
2 / 02 Currently In Use	3443	10/1/1997 14 / No	Gasoline 15,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	<input type="checkbox"/> A <input type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input type="checkbox"/> G <input type="checkbox"/> H <input checked="" type="checkbox"/> I <input checked="" type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L <input type="checkbox"/> B <input type="checkbox"/> D <input type="checkbox"/> E <input type="checkbox"/> F <input checked="" type="checkbox"/> G <input type="checkbox"/> H <input checked="" type="checkbox"/> I <input type="checkbox"/> J <input type="checkbox"/> K <input type="checkbox"/> L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: US Dept of Military Affairs Helena			Address: Disaster and Emergency Services Division, PO Box 4789, Fort Harrison MT 59636-4789		
Sys Fac ID 5613821	FITS SITE 45052	Location Name ARMY AVIATION SUPPORT FACILITY	Location Street Address 3333 SKYWAY DR	Location City HELENA, MT 59602	Location Phone (406) 324-3047
Operating Permit Renewal Date: 20-Sep-2013			Last inspected on: 22-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	827	3/1/1997 15 / No	Other 25,000	Fiberglass Reinforced Plastic Double-Walled	No Piping None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently In Use	828	3/1/1997 15 / No	Other 25,000	Fiberglass Reinforced Plastic Double-Walled	No Piping None	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Dave's Express Lube Inc			Address: 4990 N Montana Ave, Helena MT 59602-7268		
Sys Fac ID 5613828	FITS SITE 45059	Location Name DAVES EXPRESS LUBE	Location Street Address 4990 N MONTANA AVE	Location City HELENA, MT 59602	Location Phone (406) 449-9667
Operating Permit Renewal Date: 27-Jul-2013			Last inspected on: 18-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	372	1/30/1998 14 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently In Use	373	1/30/1998 14 / No	Diesel 5,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently In Use	374	1/30/1998 14 / No	Gasoline 10,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently In Use	375	1/30/1998 14 / No	Diesel 5,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Mergenthaler Transfer & Storage			Address: 1430 Carter Dr, Helena MT 59601-6429		
Sys Fac ID 5613831	FITS SITE 45060	Location Name MERGENTHALER TRANSFER & STORAGE CAR	Location Street Address 1430 CARTER DR	Location City HELENA, MT 59601	Location Phone (406) 443-7964
Operating Permit Renewal Date: 19-Mar-2015			Last inspected on: 02-Nov-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	1609	11/1/1997 14 / No	Waste Oil 3,000	STI-P3 Double-Walled	Flexible Plastic Double-Walled	Gravity Feed	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Capitol Town Pump Inc			Address: PO Box 6000, Butte MT 59702-6000		
Sys Fac ID 5613846	FITS SITE 45073	Location Name TOWN PUMP INC HELENA 4	Location Street Address 2900 N MONTANA AVE	Location City HELENA, MT 59601	Location Phone (406) 497-6700
Operating Permit Renewal Date: 29-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	2680	6/16/1998 13 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently In Use	2681	6/16/1998 13 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently In Use	2682	6/16/1998 13 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently In Use	2683	6/16/1998 13 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
5 / 05 Currently In Use	2684	7/24/1998 13 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4671	9/7/2001 10 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Donald & Barb Hulett			Address: 3044 10th Ave, Helena MT 59601-6460		
Sys Fac ID 5613934	FITS SITE 45149	Location Name EASTSIDE FUEL STOP	Location Street Address 3044 10TH AVE	Location City HELENA, MT 59601	Location Phone (406) 443-3060
Operating Permit Renewal Date: 20-Feb-2015			Last inspected on: 28-Dec-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	4145	5/1/1999 12 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
2 / 02 Currently In Use	4146	5/1/1999 12 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
3 / 03 Currently In Use	4147	5/1/1999 12 / No	Gasoline 8,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
4 / 04 Currently In Use	4148	5/1/1999 12 / No	Gasoline 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently In Use	4149	5/1/1999 12 / No	Diesel 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4150	5/1/1999 12 / No	Diesel 12,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Rocky Mountain Oil Inc			Address: Attn: Environmental Director, 4567 American Blvd W, Bloomington MN 55437		
Sys Fac ID 5613956	FITS SITE 45169	Location Name HOLIDAY #723	Location Street Address 600 N FEE ST	Location City HELENA, MT 59601	Location Phone (952) 830-8899
Operating Permit Renewal Date: 30-Mar-2013			Last inspected on: 16-Oct-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	4128	10/1/1999 12 / No	Gasoline 15,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C ● E F ● H I J K L ● ● E F ● H I J K L	Yes Yes Yes
2 / 02 Currently In Use	4129	10/1/1999 12 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C ● E F ● H I J K L ● ● E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Owner: Safeway Stores Inc			Address: 1121 124th Ave NE, Bellevue WA 98005-2101		
Sys Fac ID 5614000	FITS SITE 45206	Location Name SAFEWAY GASOLINE HELENA	Location Street Address 611 N MONTANA AVE	Location City HELENA, MT 59601	Location Phone (406) 442-6631
Operating Permit Renewal Date: 29-Jan-2014			Last inspected on: 03-Aug-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	4330	6/1/2001 10 / No	Gasoline 20,000	Composite (Steel w/ FRP) Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently In Use	4331	6/1/2001 10 / No	Gasoline 10,000	Composite (Steel w/ FRP) Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently In Use	4332	6/1/2001 10 / No	Diesel 10,000	Composite (Steel w/ FRP) Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Sprint Communications Co LLP			Address: PO Box 7994, Shawnee Mission KS 66251-6106		
Sys Fac ID 5614011	FITS SITE 45216	Location Name SPRINT HELENA POP	Location Street Address 1100 PHOENIX AVE	Location City HELENA, MT 59601	Location Phone
Operating Permit Renewal Date: 08-Aug-2014			Last inspected on: 04-Aug-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	4322	6/1/2001 10 / No	Diesel 2,500	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	U.S. Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Owner: Main Street Holdings LLC			Address: 600 S Main St, BUTTE MT 59701-2534		
Sys Fac ID 6015029	FITS SITE 45359	Location Name TOWN PUMP INC HELENA 5	Location Street Address 1822 E CUSTER AVE	Location City HELENA, MT 59602	Location Phone
Operating Permit Renewal Date: 19-Jun-2013			Last inspected on: 22-Feb-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently In Use	5064	12/6/2006 05 / No	Gasoline 20,000	Fiberglass Reinforced Plastic Double-Walled	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

2 / 02	5065	12/6/2006	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes	Yes	Yes
Currently in Use		05 / No	10,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)				
3 / 03	5066	12/6/2006	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes	Yes	Yes
Currently in Use		05 / No	8,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)				
4 / 04	5067	12/6/2006	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes	Yes	Yes
Currently in Use		05 / No	10,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)				
5 / 05	5068	12/6/2006	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes	Yes	Yes
Currently in Use		05 / No	8,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)				
6 / 06	5074	12/6/2006	Diesel	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes	Yes	Yes
Currently in Use		05 / No	10,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)				

Owner: Costco Wholesale		Address: C/O David Rogers, 999 Lake Dr, Issaquah WA 98027-8990			
Sys Fac ID 6015051	FITS SITE 45371	Location Name Costco Gasoline Helena 67	Location Street Address CUSTER AVE AND WASHINGTON ST	Location City HELENA, MT 59602	Location Phone (425) 427-7653
Operating Permit Renewal Date: 13-Nov-2014		Last inspected on: 29-Aug-2011			

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01	5095	10/5/2006	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes Yes Yes
Currently in Use		05 / No	30,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)		
2 / 02	5096	10/5/2006	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes Yes Yes
Currently in Use		05 / No	30,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)		
3 / 03	5097	10/5/2006	Gasoline	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes Yes Yes
Currently in Use		05 / No	30,000	Double-Walled	Double-Walled	(B) (E) (F) (G) (H) (I) (J) (K) (L)		
4 / 04	5281	4/12/2011	Hazardous S	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plas	Pressurized	A B C D E F G H I J K L	Yes Yes Yes
Currently in Use		01 / No	1,500	Double-Walled	Double-Walled	(B) (D) (E) (F) (G) (H) (I) (J) (K) (L)		

Owner: Montana Dept of Administration		Address: Capitol Annex General Services Division, 1310 E Lockey, Helena MT 59620			
Sys Fac ID 6015139	FITS SITE 45440	Location Name MDT EQUIPMENT DEVELOPMENT BUILDING	Location Street Address 490 18TH ST	Location City Helena, MT 59601	Location Phone (406) 444-3060
Operating Permit Renewal Date: 15-May-2014		Last inspected on: 24-Feb-2011			

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / S1	5214	10/1/2009	Diesel	Other	Flexible Plastic	Pressurized	A B C D E F G H I J K L	No No No
Currently in Use		02 / Yes	4,000	None	Double-Walled	(B) (D) (E) (F) (G) (H) (I) (J) (K) (L)		

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of HELENA

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of LINCOLN

Owner: Mountain View Coop Black Eagle			Address: Attn Pat or Frank, 2200 Old Havre Hwy, Black Eagle MT 59414-1043		
Sys Fac ID 2503995	FITS SITE 38102	Location Name MOUNTAIN VIEW COOP LINCOLN	Location Street Address 525 MAIN STREET LOT 155 LINCOLN VILLA SITES	Location City LINCOLN, MT 59639	Location Phone
Operating Permit Renewal Date: 16-Oct-2014			Last inspected on: 15-Jun-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe
							Piping Release Detection		
1 / 07 Currently in Use	2255	7/1/1996 15 / No	Diesel 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes	
5 / 04 Currently in Use	2252	7/1/1996 15 / No	Gasoline 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes	
6 / 05 Currently in Use	2253	7/1/1996 15 / No	Gasoline 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes	
7 / 06 Currently in Use	2254	7/1/1996 15 / No	Diesel 12,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F ● H I J K L	Yes Yes Yes	

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed

Facility Summary in LEWIS AND CLARK County in the City of WOLF CREEK

Owner: Shawn & Tabetha Otheim			Address: 175 Recreation Road, Wolf Creek MT 59648		
Sys Fac ID 2504132	FITS SITE 38113	Location Name CANYON STORE EXXON	Location Street Address 175 RECREATION RD	Location City WOLF CREEK, MT 59648	Location Phone (775) 527-4507
Operating Permit Renewal Date: 27-Mar-2015			Last inspected on: 24-Jan-2012		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / 03 Currently In Use	3483	11/30/1998 13 / No	Gasoline 3,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
4 / 04 Currently In Use	3484	11/30/1998 13 / No	Gasoline 7,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently In Use	3946	11/30/1998 13 / No	Diesel 4,000	Fiberglass Reinforced Plastic None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

Owner: Driftwood Enterprises LLC			Address: PO Box 3386, Great Falls MT 59403-3386		
Sys Fac ID 2505921	FITS SITE 38202	Location Name BOAT LOFT	Location Street Address 1460 BEARTOOTH RD	Location City WOLF CREEK, MT 59648	Location Phone (406) 452-3622
Operating Permit Renewal Date: 08-Jan-2015			Last inspected on: 29-Dec-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 02 Currently in Use	473	4/1/1993 19 / No	Gasoline 4,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F ● H I J K L B D E F ● H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed