

## Facility Summary in MCCONE County in the City of CIRCLE

<b>Owner:</b> Kalen Inc			<b>Address:</b> PO Box 75, Circle MT 59215-0075		
<b>Sys Fac ID</b> 2900041	<b>FITS SITE</b> 39386	<b>Location Name</b> CIRCLE SINCLAIR SERVICES	<b>Location Street Address</b> MT HIGHWAY 200 & MT HIGHWAY 13	<b>Location City</b> CIRCLE, MT 59215	<b>Location Phone</b> (406) 485-3645
<b>Operating Permit Renewal Date:</b> 30-Mar-2013			<b>Last inspected on:</b> 10-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
8 / 08 Currently In Use	612	10/1/1997 14 / No	Gasoline 6,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
9 / 09 Currently In Use	613	10/1/1997 14 / No	Diesel 2,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
10 / 10 Currently In Use	614	10/1/1997 14 / No	Diesel 2,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
11 / 11 Currently In Use	615	10/1/1997 14 / No	Diesel 6,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
12 / 12 Currently In Use	616	10/1/1997 14 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
13 / 13 Currently In Use	617	10/1/1997 14 / No	Diesel 2,000	Polyethylene Tank Jacket Double-Walled	Flexible Plastic Double-Walled	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

<b>Owner:</b> Kalen Inc			<b>Address:</b> PO Box 75, Circle MT 59215-0075		
<b>Sys Fac ID</b> 2900042	<b>FITS SITE</b> 39387	<b>Location Name</b> CIRCLE COUNTRY MARKET	<b>Location Street Address</b> MT HIGHWAY 200 & MAIN ST	<b>Location City</b> CIRCLE, MT 59215	<b>Location Phone</b> (406) 485-2680
<b>Operating Permit Renewal Date:</b> 30-Mar-2013			<b>Last inspected on:</b> 10-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / 03 Currently In Use	618	10/1/1997 14 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently In Use	619	10/1/1997 14 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in MCCONE County in the City of CIRCLE

<b>Owner:</b> School Dist 1 Circle			<b>Address:</b> 307 Meridian Ave, Circle MT 59215		
<b>Sys Fac ID</b>	<b>FITS SITE</b>	<b>Location Name</b>	<b>Location Street Address</b>	<b>Location City</b>	<b>Location Phone</b>
2900874	39394	CIRCLE PUBLIC SCHOOL DIST 1	307 S MERIDIAN AVE	CIRCLE, MT 59215	(406) 485-3600
<b>Operating Permit Renewal Date:</b> 04-Jun-2013			<b>Last inspected on:</b> 02-Feb-2010		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / S2	1890	8/1/1997	Heating Oil	Polyethylene Tank Jacket	Flexible Plastic	Safe Suction	A B C D E F G H I J K L Piping Release Detection	Yes Yes Yes
Currently In Use		14 / No	8,000	Double-Walled	Double-Walled		B D E F G H I J K L	

<b>Owner:</b> Kalen Inc			<b>Address:</b> PO Box 75, Circle MT 59215-0075		
<b>Sys Fac ID</b>	<b>FITS SITE</b>	<b>Location Name</b>	<b>Location Street Address</b>	<b>Location City</b>	<b>Location Phone</b>
2903433	39424	CIRCLE SERVICE CENTER INC	706 B Ave	CIRCLE, MT 59215	(406) 485-3645
<b>Operating Permit Renewal Date:</b>			<b>Last inspected on:</b> 12-Jun-2009		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
7 / 07	3802	11/1/1998	Gasoline	Polyethylene Tank Jacket	Flexible Plastic	Pressurized	A B C D E F G H I J K L Piping Release Detection	Yes Yes Yes
Temporarily Out of Use		13 / No	6,000	Double-Walled	Double-Walled		D E F G H I J K L	
8 / 08	3803	11/1/1998	Gasoline	Polyethylene Tank Jacket	Flexible Plastic	Pressurized	A B C D E F G H I J K L Piping Release Detection	Yes Yes Yes
Temporarily Out of Use		13 / No	4,000	Double-Walled	Double-Walled		D E F G H I J K L	
9 / 09	3804	11/1/1998	Diesel	Polyethylene Tank Jacket	Flexible Plastic	Safe Suction	A B C D E F G H I J K L Piping Release Detection	Yes Yes Yes
Temporarily Out of Use		13 / No	6,000	Double-Walled	Double-Walled		B D E F G H I J K L	

<b>Owner:</b> Hales Distributing			<b>Address:</b> PO Box 142, Circle MT 59215-0142		
<b>Sys Fac ID</b>	<b>FITS SITE</b>	<b>Location Name</b>	<b>Location Street Address</b>	<b>Location City</b>	<b>Location Phone</b>
2903684	39432	HALES DISTRIBUTING 103 MAIN ST	103 MAIN ST	CIRCLE, MT 59215	(406) 485-2510
<b>Operating Permit Renewal Date:</b> 08-Jan-2015			<b>Last inspected on:</b> 19-Oct-2011		

TankID/Alt TankID	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 05	1267	9/12/1990	Gasoline	Cathodically Protected Steel	Bare Steel	Safe Suction	A B C D E F G H I J K L Piping Release Detection	Yes Yes Yes
Currently In Use		21 / No	5,000	Double-Walled	None		D E F G H I J K L	

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in MCCONE County in the City of CIRCLE

<b>Owner:</b> Farmers Union Oil Co Circle			<b>Address:</b> PO Box 460, Circle MT 59215-0460		
<b>Sys Fac ID</b> 2906376	<b>FITS SITE</b> 39447	<b>Location Name</b> FARMERS UNION OIL CO CIRCLE	<b>Location Street Address</b> 906 AVENUE A	<b>Location City</b> CIRCLE, MT 59215	<b>Location Phone</b> (406) 485-3476
<b>Operating Permit Renewal Date:</b> 04-Mar-2013			<b>Last inspected on:</b> 10-Dec-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Installed Spill/Over/CPMe
							Piping Release Detection	
8 / S08 Currently In Use	951	11/1/1998 13 / Yes	Gasoline 15,000	Unknown None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes No
9 / S09 Currently In Use	952	11/1/1998 13 / Yes	Gasoline 15,000	Unknown None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes No
10 / S10 Currently In Use	953	11/1/1998 13 / Yes	Diesel 15,000	Unknown None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes No
11 / S11 Currently In Use	954	11/1/1998 13 / Yes	Diesel 15,000	Unknown None	Fiberglass Reinforced Plas Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes No
12 / S12 Currently in Use	5108	10/6/2006 05 / Yes	Diesel 5,000	Not Listed None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes No

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in MCCONE County in the City of VIDA

<b>Owner:</b> Farmers Union Oil Co Wolf Point			<b>Address:</b> DBA Agland Coop, 60 US Highway 2 E, Wolf Point MT 59201-1942		
<b>Sys Fac ID</b> 5614042	<b>FITS SITE</b> 45242	<b>Location Name</b> AGLAND COOP	<b>Location Street Address</b> MT HIGHWAY 13	<b>Location City</b> VIDA, MT 59274	<b>Location Phone</b> (406) 525-3207
<b>Operating Permit Renewal Date:</b> 18-Feb-2013			<b>Last inspected on:</b> 21-Aug-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection		Installed Spill/Over/CPMe
							Piping Release Detection		
1 / 01 Currently In Use	4560	12/1/2001 10 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I J ● K L	Yes Yes Yes	
2 / 02 Currently In Use	4561	12/1/2001 10 / No	Diesel 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● J K L	Yes Yes Yes	
3 / 03 Currently In Use	4562	12/1/2001 10 / No	Diesel 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Safe Suction	A B C ● E F G H I J K L B D E F G H I ● K L	Yes Yes Yes	

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed