

Facility Summary in PETROLEUM County in the City of WINNETT

Owner: GS Oil Inc Roy			Address: PO Box 149, Roy MT 59471-0149		
Sys Fac ID 3500536	FITS SITE 40713	Location Name WINNETT TIRE	Location Street Address ROUTE 244	Location City WINNETT, MT 59087	Location Phone (406) 429-2961
Operating Permit Renewal Date: 17-Jun-2013			Last inspected on: 08-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
3 / S3 Currently In Use	4094	9/27/1999 12 / Yes	Gasoline 2,000	Asphalt Coated or Bare Steel Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	No No Yes
4 / S4 Currently In Use	4095	9/27/1999 12 / Yes	Gasoline 3,000	Asphalt Coated or Bare Steel Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F <input checked="" type="radio"/> H I J K L	No No Yes
5 / S5 Currently In Use	4096	9/27/1999 12 / Yes	Diesel 3,000	Asphalt Coated or Bare Steel Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	No No Yes
6 / S6 Currently In Use	4097	9/27/1999 12 / Yes	Diesel 3,000	Asphalt Coated or Bare Steel Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	No No Yes

Owner: B & D Service			Address: PO Box 229, Winnett MT 59087-0229		
Sys Fac ID 5613897	FITS SITE 45115	Location Name B & D SERVICE HWY 244	Location Street Address 203 N BROADWAY AVE RR 244	Location City WINNETT, MT 59087	Location Phone (406) 429-5291
Operating Permit Renewal Date: 26-Jan-2013			Last inspected on: 24-Sep-2009		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / S5 Currently In Use	4001	4/1/1999 13 / Yes	Gasoline 12,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes
6 / S6 Currently In Use	4002	4/1/1999 13 / Yes	Diesel 12,000	Unknown None	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J <input checked="" type="radio"/> K L B D E F <input checked="" type="radio"/> H I J K L	Yes Yes Yes

Tank/Piping Release Detection Codes

A Manual Tank Gauging	C Inventory Control	E Vapor Monitoring	G Interstit. Dbl-Wall Monitor	I SIR	K Deferred
B Tank/Line Tightness Testing	D ATG/Auto Line LD	F GW Monitoring	H Interstit. Sec. Con. Monitor	J Other Methods	L Not Listed