

## Facility Summary in SWEET GRASS County in the City of BIG TIMBER

<b>Owner:</b> J Diamond L Inc			<b>Address:</b> PO Box 1343, Big Timber MT 59011-1343		
<b>Sys Fac ID</b> 4902680	<b>FITS SITE</b> 43197	<b>Location Name</b> THE FORT	<b>Location Street Address</b> 228 BIG TIMBER LOOP	<b>Location City</b> BIG TIMBER, MT 59011	<b>Location Phone</b>
<b>Operating Permit Renewal Date:</b> 19-Mar-2015			<b>Last inspected on:</b> 26-Oct-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
4 / 04 Currently in Use	3229	8/1/1996 15 / No	Gasoline 10,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
5 / 05 Currently in Use	3230	8/1/1996 15 / No	Diesel 4,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
6 / 06 Currently in Use	3231	8/1/1996 15 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes
7 / 07 Currently in Use	5052	10/31/2005 06 / No	Gasoline 20,000	STI-P3 None	Flexible Plastic Double-Walled	Pressurized	A B C ● E F G H I J K L B D E F ● H I J K L	Yes Yes Yes

<b>Owner:</b> GM Petroleum			<b>Address:</b> PO Box 30335, Billings MT 59107-0335		
<b>Sys Fac ID</b> 4906069	<b>FITS SITE</b> 43227	<b>Location Name</b> SWEET GRASS CENEX	<b>Location Street Address</b> 202 E 1ST AVE	<b>Location City</b> BIG TIMBER, MT 59011	<b>Location Phone</b> (406) 932-5183
<b>Operating Permit Renewal Date:</b> 19-Mar-2015			<b>Last inspected on:</b> 06-Dec-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 10 Currently in Use	3469	12/10/1990 21 / No	Gasoline 10,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
9 / 08 Currently in Use	3467	12/10/1990 21 / No	Gasoline 6,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
10 / 09 Currently in Use	3468	12/10/1990 21 / No	Gasoline 8,000	STI-P3 None	Fiberglass Reinforced Plas None	Pressurized	A B C ● E F G H I J K L ● E F G H I J K L	Yes Yes Yes
11 / S11 Currently in Use	5050	2/10/2006 06 / Yes	Diesel 12,000	Concrete None	Flexible Plastic None	Pressurized	A B C D E F G H I J ● L ● E F G H I J K L	Yes Yes Yes
12 / S12 Currently in Use	5051	2/10/2006 06 / Yes	Diesel 12,000	Concrete None	Flexible Plastic None	Pressurized	A B C D E F G H I J ● L ● E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in SWEET GRASS County in the City of BIG TIMBER

<b>Owner:</b> Big Timber Holdings LLC			<b>Address:</b> PO Box 6000, Butte MT 59702-6000		
<b>Sys Fac ID</b> 4909311	<b>FITS SITE</b> 43254	<b>Location Name</b> BIG TIMBER TOWN PUMP AND CASINO	<b>Location Street Address</b> INTERSTATE 90 & US HIGHWAY 10 W	<b>Location City</b> BIG TIMBER, MT 59011	<b>Location Phone</b> (406) 932-4419
<b>Operating Permit Renewal Date:</b> 24-Aug-2013			<b>Last inspected on:</b> 29-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
5 / 05 Currently In Use	4828	4/30/2003 08 / No	Gasoline 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4829	4/30/2003 08 / No	Gasoline 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
7 / 07 Currently In Use	4830	4/30/2003 08 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
8 / 08 Currently In Use	4831	4/30/2003 08 / No	Diesel 8,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

<b>Owner:</b> Town Pump of Big Timber Inc			<b>Address:</b> PO Box 6000, Butte MT 59702-6000		
<b>Sys Fac ID</b> 4913756	<b>FITS SITE</b> 43271	<b>Location Name</b> TOWN PUMP INC BIG TIMBER 1ST AVE	<b>Location Street Address</b> 510 W 1ST AVE	<b>Location City</b> BIG TIMBER, MT 59011	<b>Location Phone</b> (406) 932-5349
<b>Operating Permit Renewal Date:</b> 19-Sep-2013			<b>Last inspected on:</b> 29-Mar-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 01 Currently in Use	2652	8/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 02 Currently in Use	2653	10/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 03 Currently in Use	2654	10/1/1996 15 / No	Gasoline 12,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 04 Currently in Use	2655	10/1/1996 15 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
5 / 05 Currently in Use	2656	10/1/1996 15 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
6 / 06 Currently In Use	4649	5/1/2002 09 / No	Diesel 10,000	Fiberglass Reinforced Plastic Double-Walled	Flexible Plastic Double-Walled	Pressurized	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

**Facility Summary in SWEET GRASS County in the City of BIG TIMBER**

7 / 07  
Currently in Use

**4650**

5/1/2002  
09 / No

Diesel  
5,000

Fiberglass Reinforced Plastic  
Double-Walled

Flexible Plastic  
Double-Walled

Pressurized

<input type="radio"/> A	<input type="radio"/> B	<input type="radio"/> C	<input type="radio"/> D	<input type="radio"/> E	<input type="radio"/> F	<input checked="" type="radio"/> G	<input type="radio"/> H	<input type="radio"/> I	<input type="radio"/> J	<input type="radio"/> K	<input type="radio"/> L
<input type="radio"/> B	<input type="radio"/> D	<input type="radio"/> E	<input type="radio"/> F	<input checked="" type="radio"/> G	<input type="radio"/> H	<input type="radio"/> I	<input type="radio"/> J	<input type="radio"/> K	<input type="radio"/> L		

Yes Yes Yes

**Tank/Piping Release Detection Codes**

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed