

## Facility Summary in WIBAUX County in the City of WIBAUX

<b>Owner:</b> Wibaux County Shop			<b>Address:</b> Attn Kim Bacon, 225 2nd Ave NW, Wibaux MT 59353-9219		
<b>Sys Fac ID</b> 5502446	<b>FITS SITE</b> 44199	<b>Location Name</b> WIBAUX COUNTY UST	<b>Location Street Address</b> 2ND AVE N PO BOX 86	<b>Location City</b> WIBAUX, MT 59353	<b>Location Phone</b> (406) 796-2446
<b>Operating Permit Renewal Date:</b> 15-Oct-2013			<b>Last inspected on:</b> 20-Jul-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
2 / 04 Currently in Use	2272	6/1/1995 16 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Bare Steel none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
3 / 05 Currently in Use	2273	6/1/1995 16 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Bare Steel none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
4 / 06 Currently in Use	2274	6/1/1995 16 / No	Waste Oil 500	Polyethylene Tank Jacket Double-Walled	Bare Steel none	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes No Yes

<b>Owner:</b> Wibaux Coop Oil Co			<b>Address:</b> PO Box 178, Wibaux MT 59353-0178		
<b>Sys Fac ID</b> 5503348	<b>FITS SITE</b> 44201	<b>Location Name</b> WIBAUX COOP OIL CO	<b>Location Street Address</b> 203 2ND AVE NW	<b>Location City</b> WIBAUX, MT 59353	<b>Location Phone</b> (406) 795-2219
<b>Operating Permit Renewal Date:</b> 23-Oct-2013			<b>Last inspected on:</b> 20-Jul-2010		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection Piping Release Detection	Installed Spill/Over/CPMe
1 / 10 Currently in Use	2270	6/1/1995 16 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
2 / 11 Currently in Use	2271	6/1/1995 16 / No	Diesel 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
8 / 07 Currently in Use	2267	6/1/1995 16 / No	Gasoline 5,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
9 / 08 Currently in Use	2268	6/1/1995 16 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes
10 / 09 Currently in Use	2269	6/1/1995 16 / No	Gasoline 4,000	Polyethylene Tank Jacket Double-Walled	Fiberglass Reinforced Plas None	Safe Suction	A B C D E F G H I J K L B D E F G H I J K L	Yes Yes Yes

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed

## Facility Summary in WIBAUX County in the City of WIBAUX

<b>Owner:</b> Amsler C Store			<b>Address:</b> PO Box 16, Wibaux MT 59353-0016		
<b>Sys Fac ID</b> 5513559	<b>FITS SITE</b> 44222	<b>Location Name</b> AMSLER C STORE	<b>Location Street Address</b> 102 2ND AVE N	<b>Location City</b> WIBAUX, MT 59353	<b>Location Phone</b> (406) 796-2338
<b>Operating Permit Renewal Date:</b> 22-Aug-2014			<b>Last inspected on:</b> 16-Jul-2011		

TankID/Alt TankID Status	Tag Number	Installed Age/AST	Product Capacity	Tank Mat'l of Construction Secondary Option	Piping Material Secondary Option	Piping Type	Tank Release Detection	Installed Spill/Over/CPMe																									
							Piping Release Detection																										
1 / 01 Currently in Use	3258	11/1/1994 17 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic none	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td></td><td>B</td><td></td><td></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L		B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																						
	B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																					
2 / 02 Currently in Use	3259	1/1/1994 18 / No	Diesel 4,000	STI-P3 None	Flexible Plastic none	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td></td><td>B</td><td></td><td></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L		B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																						
	B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																					
3 / 03 Currently in Use	3260	1/1/1994 18 / No	Gasoline 6,000	STI-P3 None	Flexible Plastic none	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td></td><td>B</td><td></td><td></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L		B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																						
	B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																					
4 / 04 Currently in Use	3261	1/1/1994 18 / No	Gasoline 4,000	STI-P3 None	Flexible Plastic none	Safe Suction	<table border="1" style="font-size: small;"> <tr><td>A</td><td>B</td><td>C</td><td><input checked="" type="checkbox"/></td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td>J</td><td>K</td><td>L</td></tr> <tr><td></td><td>B</td><td></td><td></td><td>D</td><td>E</td><td>F</td><td>G</td><td>H</td><td>I</td><td><input checked="" type="checkbox"/></td><td>K</td><td>L</td></tr> </table>	A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L		B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L	Yes Yes Yes
A	B	C	<input checked="" type="checkbox"/>	E	F	G	H	I	J	K	L																						
	B			D	E	F	G	H	I	<input checked="" type="checkbox"/>	K	L																					

### Tank/Piping Release Detection Codes

<b>A</b> Manual Tank Gauging	<b>C</b> Inventory Control	<b>E</b> Vapor Monitoring	<b>G</b> Interstit. Dbl-Wall Monitor	<b>I</b> SIR	<b>K</b> Deferred
<b>B</b> Tank/Line Tightness Testing	<b>D</b> ATG/Auto Line LD	<b>F</b> GW Monitoring	<b>H</b> Interstit. Sec. Con. Monitor	<b>J</b> Other Methods	<b>L</b> Not Listed