

Petroleum Tank Release Compensation Board

Aboveground Storage Tank (Attached to a Burner)

Self-Inspection Checklist

		Tank #	Tank #	Tank #	Tank #	Tank #
1	Is the metal aboveground heating oil tank welded or brazed or both? (ARM 17.58.326(1)(d)(i))	YES NO	YES NO	YES NO	YES NO	YES NO
2	Is the aboveground heating oil tank resting on the ground or on a foundation made of concrete, masonry, piling, or steel? (ARM 17.58.326(1)(d)(ii))	YES NO	YES NO	YES NO	YES NO	YES NO
3	Is the aboveground heating oil tank foundation designed to minimize the possibility of uneven settling and to minimize corrosion in any part of the tank resting on the foundation? (ARM 17.58.326(1)(d)(iii))	YES NO	YES NO	YES NO	YES NO	YES NO
4	Is the foundation for the aboveground heating oil tank a single wood timber support (no cribbing), laid horizontally and less than 12 inches highest at the lowest point? (ARM 17.58.326(1)(d)(iv))	YES NO	YES NO	YES NO	YES NO	YES NO
5	Is the outside aboveground heating oil tank, appurtenances, and supports protected from external corrosion? (ARM 17.58.326(1)(d)(v))	YES NO	YES NO	YES NO	YES NO	YES NO
6	Is there a shutoff valve at the tank on the gravity supply line between the aboveground heating oil tank and burner? (ARM 17.58.326(1)(d)(vi))	YES NO	YES NO	YES NO	YES NO	YES NO
7	Is the aboveground heating oil tank liquidtight? (ARM 17.58.326(1)(d)(vii))	YES NO	YES NO	YES NO	YES NO	YES NO
8	If the tank is temporarily or permanently removed from service has it been emptied of all contents? (ARM 17.58.326(1)(d)(viii)), (ARM 17.58.326(1)(d)(ix))	YES NO N/A	YES NO N/A	YES NO N/A	YES NO N/A	YES NO N/A
9	Is the piping supported and protected against physical damage? (ARM 17.58.326(1)(d)(x)(A))	YES NO	YES NO	YES NO	YES NO	YES NO
10	Is the piping protected against corrosion?(ARM 17.58.326(1)(d)(x)(B))	YES NO	YES NO	YES NO	YES NO	YES NO
11	Is the piping maintained liquid tight? (ARM 17.58.326(1)(d)(xi))	YES NO	YES NO	YES NO	YES NO	YES NO
12	If required by 40 CFR Section 112, do you have a Spill Prevention, Control and Countermeasure Plan? (ARM 17.58.326(1)(e))	Yes/ No/ Not Required				
Comments:						