

## 90<sup>th</sup> Percentile Calculation – EXAMPLES:

### Systems that collect 5 samples

1. Order lead results from lowest to highest:

No 1: 0.008 mg/L

No 2: 0.008 mg/L

No 3: 0.008 mg/L

No 4: 0.011 mg/L

No 5: 0.020 mg/L

→ PB90 = 0.0155 mg/L

2. Multiply number of samples by 0.9 to determine which sample represents 90th percentile level.

5 samples \* 0.9 = 4.5 (average of the 4<sup>th</sup> and 5<sup>th</sup> highest sample results).

Average the 4th & 5th samples highest sample results to get 90th percentile value  
(0.011 mg/L + 0.020 mg/L)/2 = **0.0155 mg/L**

3. Compare to lead action level exceedance

PB90 0.0155 mg/L > 0.015 mg/L (Action Level Exceedance)

4. Repeat for copper.

### Systems that collect 10 samples

1. Order lead results from lowest to highest :

No. 1: 0.005                      No. 6: 0.014

No. 2: 0.005                      No. 7: 0.014

No. 3: 0.005                      No. 8: 0.014

No. 4: 0.005                      No. 9: 0.020

No. 5: 0.014                      No. 10: 0.040

→ PB90 = 0.020 mg/L

2. Multiply number of samples by 0.9 to determine which sample represents 90th percentile level

10 samples x 0.9 = 9th highest sample

3. Compare to lead action level exceedance

PB90 0.02 mg/L > 0.015 mg/L (Action Level Exceedance)

4. Repeat for copper.

### Systems that collect less than 5 samples

1. PB90 and CU90 are equal to the highest lead and copper levels.

# 90<sup>th</sup> Percentile Calculation - DEQ REPORTS

Go to: <http://www.deq.mt.gov/wqinfo/pws/reports.asp>.

The image displays two screenshots from the Montana Department of Environmental Quality (DEQ) website. The left screenshot shows the 'Public Water Supply Online Query Reports' page. A callout box points to the 'Active PWS System Data' option under the 'Public Water Supply Online Query Reports' section. The right screenshot shows the 'Lead & Copper Sample Summaries' report. A callout box points to the data table in the report.

**Public Water Supply Online Query Reports**

These reports allow you to generate a report by selecting various criteria. Report returns data from active systems only.

- Active PWS System Data** - select by PWSID, system name or county and date range for back and chemical samples and violation data.
- Active PWS System Back Data** - select back sample data for a specific PWSID.
- PWS System Nitrate Results** - select nitrate results for a specific PWSID.

Hint: If you get an error please wait 30 minutes or so and try again in case the server is down.

If you have any questions about the report contact the [Rule Specialists](#).

The query will generate an Adobe Acrobat pdf format report. You can download this free software by clicking this link. [Download Acrobat Reader](#).

**Public Water Supply Online Query Reports**

**Lead & Copper Sample Summaries** FROM 01/01/1992 TO 06/12/2009

Period Begin	Period End	Collection End	Type	Period Name	Code	Count	Measure	UoM
01/01/2009	06/30/2009	05/13/2009	6M	1ST 6M 09	PB90	5	0125	MG/L
01/01/2009	06/30/2009	05/13/2009	6M	1ST 6M 09	CU90	5	225	MG/L
07/01/2008	12/31/2008	11/4/2008	6M	6M 200802	PB90	6	0074	MG/L
07/01/2008	12/31/2008	11/4/2008	6M	6M 200802	CU90	6	1625	MG/L
01/01/2008	06/30/2008	04/30/2008	6M	6M 200801	PB90	6	0191	MG/L
01/01/2008	06/30/2008	04/08/2008	6M	6M 200801	CU90	11	2267	MG/L
07/01/2007	12/31/2007	12/17/2007	6M	2ND 6M 07	PB90	6	0378	MG/L
07/01/2007	12/31/2007	12/17/2007	6M	2ND 6M 07	CU90	6	0796	MG/L
01/01/2007	06/30/2007	02/15/2007	6M	1ST 6M 07	PB90	5	0165	MG/L
01/01/2007	06/30/2007	02/15/2007	6M	1ST 6M 07	CU90	5	1795	MG/L
01/01/2006	06/30/2006	05/25/2006	6M	1ST 6M 06	PB90	5	0135	MG/L
01/01/2006	06/30/2006	05/25/2006	6M	1ST 6M 06	CU90	5	169	MG/L

**Violations & Enforcements** FROM 01/01/2009 TO 06/12/2009

Viol Date	Comp B/g	Comp End	Fed F	Viol No	Type	Sev	Cate	Code	Name
-----------	----------	----------	-------	---------	------	-----	------	------	------

Select Active PWS System Data, after the jump, enter your PWSID and dates of interest and select "Submit Query".

Lead & Copper Sample Summaries or 90<sup>th</sup> percentiles are listed on the last page of the report just above Violations & Enforcements.